

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0960011	AQUARION WATER CO OF CT-NEW MILFORD	C	7,121	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					3,458

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (0999)		10 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Asbestos (1094)		3 routine (RT) per nine years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20		
Total Coliform (3100)		10 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		2 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
CAMELOT TANK - NM (04516)	1/1/18 - 12/31/18	8/1-8/31	Complete
	1/1/19 - 12/31/19	8/1-8/31	
	1/1/20 - 12/31/20	8/1-8/31	
LADY OF LAKES OFFICE (04526)	1/1/18 - 12/31/18	8/1-8/31	Complete
	1/1/19 - 12/31/19	8/1-8/31	
	1/1/20 - 12/31/20	8/1-8/31	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0960011	AQUARION WATER CO OF CT-NEW MILFORD	C	7,121	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					3,458

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Lead And Copper (PBCU) 20 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/19	6/1-9/30	
	1/1/20 - 12/31/20	6/1-9/30	

Physical Parameters (PPS) 10 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: PEAGLER HILL WTP - WELL #1 ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT #1 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Uranium (4006) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT #1 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT #1 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT #1 (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT #1 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0960011	AQUARION WATER CO OF CT-NEW MILFORD	C	7,121	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					3,458

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: PEAGLER HILL WTP - WELL #1 ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/20		

Pesticides, Herbicides and PCBs-Phase II (SOC2) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT #1 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Pesticides, Herbicides and PCBs-Phase V (SOC5) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT #1 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT #1 (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: PEAGLER HILL WTP - WELLS #2/#3 ENTRY PT (WSF ID: 00701)

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PEAGLER WELLS 2&3 - EP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PEAGLER WELLS 2&3 - EP (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA) 1 routine (RT) per six years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PEAGLER WELLS 2&3 - EP (3)	1/1/16 - 12/31/21		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PEAGLER WELLS 2&3 - EP (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PEAGLER WELLS 2&3 - EP (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Water System Facility: INDIAN FIELD WELLFIELD ENTRY POINT (WSF ID: 00702)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0960011	AQUARION WATER CO OF CT-NEW MILFORD	C	7,121	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					3,458

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: INDIAN FIELD WELLFIELD ENTRY POINT (WSF ID: 00702)

Gross Beta Particle Activity (4100)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
INDIAN FIELD ENTRY POINT (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
Man-Made Beta Particle & Photon Emitters (4101)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
INDIAN FIELD ENTRY POINT (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
Tritium (4102)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
INDIAN FIELD ENTRY POINT (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
Strontium-90 (4174)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
INDIAN FIELD ENTRY POINT (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
INDIAN FIELD ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
INDIAN FIELD ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per six years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
INDIAN FIELD ENTRY POINT (3)	1/1/17 - 12/31/22		Complete
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
INDIAN FIELD ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
INDIAN FIELD ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0960011	AQUARION WATER CO OF CT-NEW MILFORD	C	7,121	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					3,458

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: INDIAN FIELD WELLFIELD ENTRY POINT (WSF ID: 00702)

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/20		

Water System Facility: PEAGLER HILL WELLFIELD - WELL #1 (WSF ID: 1167)

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #1 (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: PEAGLER HILL WELLFIELD - WELL #2 (WSF ID: 1168)

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #2 (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: PEAGLER HILL WELLFIELD - WELL #3 (WSF ID: 1169)

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #3 (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: INDIAN FIELD WELLFIELD - WELL #4 (WSF ID: 1737)

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #4 (2)	10/1/18 - 12/31/18		
	1/1/19 - 3/31/19		
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: INDIAN FIELD WELLFIELD - WELL #6 (WSF ID: 1833)

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #6 (2)	10/1/18 - 12/31/18		
	1/1/19 - 3/31/19		
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: INDIAN FIELD WELLFIELD - WELL #5A (WSF ID: 58920)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0960011	AQUARION WATER CO OF CT-NEW MILFORD	C	7,121	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					3,458
					Agricultural

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: INDIAN FIELD WELLFIELD - WELL #5A (WSF ID: 58920)

E. Coli (3014)

1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
INDIAN FIELD-WELL 5A (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: PEAGLER HILL WTP - WELL #1 ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 5/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 10 MG/L	2
Start Date: 10/1/2012	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		

Water System Facility: PEAGLER HILL WTP - WELLS #2/#3 ENTRY PT (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 3/1/2014	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960011	AQUARION WATER CO OF CT-NEW MILFORD			C	7,121	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						3,458	

Towns Served: NEW MILFORD

Water System Facility: INDIAN FIELD WELLFIELD ENTRY POINT (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 9/1/2014			
		Compliance History: Monitoring Period	Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	N
		12/1/2018 - 12/31/2018	N
		1/1/2019 - 1/31/2019	N
		2/1/2019 - 2/28/2019	N
		3/1/2019 - 3/31/2019	N
		4/1/2019 - 4/30/2019	N
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 10 MG/L	2
Start Date: 9/1/2014			
		Compliance History: Monitoring Period	Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	N
		12/1/2018 - 12/31/2018	N
		1/1/2019 - 1/31/2019	N
		2/1/2019 - 2/28/2019	N
		3/1/2019 - 3/31/2019	N
		4/1/2019 - 4/30/2019	N

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification Required	Public Notification Performed	PN Certification Due to DPH	PN Certification Received
Lead and Copper M&R Violation	1/1/17 - 12/31/17	3	1/10/2019		1/20/2019	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	04516	CAMELOT TANK - NM	A	Y		Y	Y
		04517	SCHAGICOKE MS-NM	A	Y			
		04518	VILLAGE CREST NH-NM	A	Y			
		04519	NEW MILFORD HOSPITAL	A	Y			
		04520	CRAIG MEIER INS - NM	A	Y		Y	
		04521	MCDONALDS - NM	A	Y		Y	
		04522	B&B MASON - NM	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name		Classification	Population	Owner Type	Primary Source	
CT0960011	AQUARION WATER CO OF CT-NEW MILFORD		C	7,121	P	GW	
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						3,458	

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		04523	NAUTILUS GYM - NM	A	Y			
		04524	NEW MILFORD SPORTS	A	Y			
		04525	NM TENNIS AND SWIM C	A	Y			
		04526	LADY OF LAKES OFFICE	A	Y			Y
		04527	SCHAGICIOKE MS SS	A	Y			
		04528	MEDINSTILL - NM	A	Y			
		04608	INDIAN RIDGE SS	A	Y			
		04608D	INDIAN RIDGE SS - DO	A	Y			
		04608U	INDIAN RIDGE SS - UP	A	Y			
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		NM-	180 DANBURY ROAD	A	Y		Y	
		NM-1	48 DANBURY ROAD	A	Y			
		NM-10	19 POPLAR STREET	A	Y			
		NM-11	4 MARE LANE	A	Y			
		NM-12	86 VALLEY VIEW LANE	A	Y			
		NM-13	6 ROUND TABLE ROAD	A	Y			
		NM-14	3 STEPHANIE DRIVE	A	Y			
		NM-15	10 STILL RIVER ROAD	A	Y			
		NM-16	23 ORCHARD HEIGHTS	A			3	
		NM-17	2 TALL OAKS	A	Y		1	
		NM-18	9 NEW STREET	A			3	
		NM-19	25 FLOWER HILL ROAD	A			3	
		NM-2	1 BROOK VIEW LANE	A	Y			
		NM-20	101 SULLIVAN FARM	A			1	
		NM-21	3 ROBIN RIDGE	A			3	
		NM-22	191 WELLSVILLE AVE	A			3	
		NM-23	15 OLD ORCHARD LANE	A			3	
		NM-24	12 SANTA LANE	A			3	
		NM-25	12 OLD TOWN PARK ROA	A			3	
		NM-26	63 FORDYCE ROAD	A			3	
		NM-27	5 SCHAGHTCOKE TRAIL	A			1	
		NM-28	11 BLUE BONNETT KNL	A			3	
		NM-29	26 HILLSIDE AVENUE	A			3	
		NM-3	65 VALLEY DRIVE	A	Y			
		NM-30	2 PALOMINO DRIVE	A	Y		3	Y
		NM-31	111 LONE OAK DRIVE	A	Y		3	Y
		NM-32	106 VALLEY DRIVE	A			1	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960011	AQUARION WATER CO OF CT-NEW MILFORD			C	7,121	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						3,458	

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		NM-33	58 WILLOW SPRING	A		1		
		NM-34	3 SHERRY LANE	A		3		
		NM-35	61 CROSSBROOK ROAD	A		3		
		NM-36	11 BEARD DRIVE	A		1		
		NM-37	56 BEARD DRIVE	A		1		
		NM-38	61 BEARD DRIVE	A		1		
		NM-39	27 PARK LANE WEST	A		3		
		NM-4	SULLIVAN FARMS POOL	A	Y			
		NM-40	4 ROBIN RIDGE	A		1		
		NM-41	10 BROOKVIEW LANE	A	Y	1	Y	
		NM-42	61 CROSSBROOK ROAD	A		3		
		NM-43	63 CROSSBROOK ROAD	A		3		
		NM-44	23 ORCHARD HEIGHTS	A		3		
		NM-45	31 UPPER VALLEY ROAD	A		1		
		NM-46	105 VALLEY VIEW DRIV	A		1		
		NM-47	12 TERRACE PLACE	A		3		
		NM-48	6 SULLIVAN FARM ROAD	A		1		
		NM-49	3 VAN CAR ROAD	A		1		
		NM-5	123 LITCHFIELD ROAD	A	Y			
		NM-50	19 BROOKVIEW LANE	A	Y			
		NM-51	103 VALLEY DRIVE	A	Y			
		NM-52	93 SULLIVAN FARM ROA	A	Y			
		NM-53	108 SULLIVAN FARM RO	A	Y			
		NM-54	48 LANESVILLE ROAD	A	Y			
		NM-55	121 LICHFIELD ROAD	A	Y			
		NM-56	130 GROVE STREET	A	Y			
		NM-57	10 GOODHILL ROAD	A	Y			
		NM-58	5 OLD TOWN PARK ROAD	A	Y			
		NM-59	126 HOUSATONIC AVE	A	Y			
		NM-6	11 ANDERSON AVE	A	Y			
		NM-60	4 MAPLE STREET	A	Y			
		NM-61	19 COBBLER	A	Y			
		NM-62	16 FORDYCE ROAD	A	Y			
		NM-63	28 BRENTWOOD ROAD	A	Y			
		NM-64	22 HIPPO ROAD	A	Y		Y	
		NM-65	30 PARK LANE EAST	A	Y		Y	
		NM-7	10 HIGH VIEW ROAD	A	Y			
		NM-8	84 SO END PLAZA	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0960011	AQUARION WATER CO OF CT-NEW MILFORD			C	7,121	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							3,458	

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		NM-9	116 HOUSATONIC AVE	A	Y			
		PB7373	PB7373 - 26 PARK LAN	A	Y	3		
		PB7374	PB7374 - 5 BRADBURY	A	Y	3		
		PB7376	PB7376 - 14 TERRACE	A	Y	3		
		PB7377	PB7377 - 139 PERRY D	A	Y	3		
		PB7378	PB7378 - 114 PERRY D	A	Y	3		
		PB7379	41 PERRY DR	A	Y	3		
		PB7380	PB7380 - 46 PERRY DR	A	Y	3		
		PB7381	63 HEACOCK CROSSBRK	A		1		
		PB7382	PB7382 - 8 OLD ORCHA	A	Y	3		
		PB7383	PB7383 - 31 AVERY RD	A	Y	3		
		PB7384	PB7384 - 9 NEW ST RD	A	Y	3		
		PB7385	PB7385 - 98 GROVE ST	A	Y	3		
		PB7386	PB7386 - 2 HIGHVIEW	A	Y	3		
		PB7387	11 VAN CAR RD	A	Y	1		
		PB7388	PB7388 - 61 HEACOCK	A	Y	3		
		PB7389	PB7389 - 15 OLD ORCH	A	Y	3		
		PB7390	PB7390 - 6 OLD ORCHA	A	Y	3		
		PB7392	PB7392 - 10 BRADBURY	A	Y	3		
		PB7393	PB7393 - 30 BRADBURY	A	Y	3		
		PB7394	PB7394 - 11 BLUE BON	A	Y	3		
		PB7395	PB7395 - 111 LONE OA	A	Y	3		
		PB7396	PB7396 - 3 SHERRY LA	A	Y	3		
		PB7397	10 BROOKVIEW LN	A	Y	1		
		PB7398	4 ROBIN RIDGE	A	Y	1		
		PB7399	PB7399 - 27 PARK LAN	A	Y	3		
		PB7400	PB7400 - 6 SULLIVAN	A	Y	1		
		PB7401	9 BROOKVIEW LN	A	Y	1		
		PB7402	5 BROOKVIEW LN	A	Y	1		
		PB7403	PB7403 - 11 BRADBURY	A	Y	3		
		PB7404	3 VAN CAR RD	A	Y	1		
		PB7405	PB7405 - 5 ROBIN RID	A	Y	3		
		PB7406	PB7406 - 65 VALLEY R	A	Y	1		
		PB7407	PB7407 - 26 HILLSIDE	A	Y	3		
		PB7408	PB7408 - 32 HILLSIDE	A	Y	3		
		PB7410	PB7410 - 47 PERRY DR	A	Y	3		
		PB7411	2 OLD ORCHARD LN	A	Y	1		
		PB7412	PB7412 - 1 OLD ORCHA	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960011	AQUARION WATER CO OF CT-NEW MILFORD			C	7,121	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						3,458	

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB7414	PB7414 - 106 VALLEY	A	Y	1		
		PB7416	PB7416 - 201 GROVE S	A	Y	3		
		PB7417	PB7417 - 26 BRADBURY	A	Y	3		
		PB7418	PB7418 - 22 AVERY RD	A	Y	3		
		PB7419	PB7419 - 33 AVERY RD	A	Y	3		
		PB7420	9 VAN CAR RD	A	Y	1		
		PB7421	PB7241-6 SOUTH MAIN	A	Y	3		
		PB7479	12 WAMPUM DRIVE	A	Y	3		
		PB7480	4 ARROWHEAD PLACE	A	Y	3		
		PB7481	14 INDIAN RIDGE ROAD	A	Y	3		
		PB7482	21 INDIAN RIDGE ROAD	A	Y	3		
		PB7483	18 INDIAN RIDGE ROAD	A	Y	3		
		PB7484	8 WAMPUM DRIVE	A	Y	3		
		PB7932	3 TAYLOR TERRACE	A		1		
		PB7933	4 STEPHANIE DR	A		1		
		PB7934	12 STEPHANI	A		1		
		PB7935	17 STEPHANIE DR	A		1		
		PB7936	21 STEPHANIE DR	A		1		
		PB7937	31 STEPHANIE DR	A		1		
		PB7938	57 TAYLOR TERRACE	A		1		
		PB7939	67 TAYLOR TERRACE	A		1		
		PB7940	115 GROVE ST	A		1		
		PB7941	175 WELLSVILLE AVE	A		1		
		PB7942	244 WELLSVILLE AVE	A		1		
		PB7943	48 PROSPECT HILL RD	A		1		
		PB7944	12 LEGION RD	A		1		
		PB7945	1 BROOKVIEW LANE	A		1		
		PB7946	2 BROOKVIEW LANE	A		1		
		PB7947	4 BROOKVIEW LANE	A		1		
		PB7948	6 BROOKVIEW LANE	A		1		
		PB7949	8 BROOKVIEW LANE	A		1		
		PB7950	33 STEPHANIE DR	A		1		
		PB7951	37 STEPHANIE DR	A		1		
		PB7952	39 STEPHANIE DR	A		1		
		PB8012	7 BROOKVIEW LANE	A		1		
		PB80212	7 BROOK VIEW LANE	A		1		
		PB8596	23 STEPHANIE DR	A		1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0960011	AQUARION WATER CO OF CT-NEW MILFORD			C	7,121	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							3,458	

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00700	PEAGLER HILL WTP - WELL #1 ENTRY POINT	3	ENTRY POINT #1	A				
00701	PEAGLER HILL WTP - WELLS #2/#3 ENTRY PT	3	PEAGLER WELLS 2&3 -	A				
00702	INDIAN FIELD WELLFIELD ENTRY POINT	3	INDIAN FIELD ENTRY P	A				
1167	PEAGLER HILL WELLFIELD - WELL #1	2	WELL #1	A				
1168	PEAGLER HILL WELLFIELD - WELL #2	2	WELL #2	A				
1169	PEAGLER HILL WELLFIELD - WELL #3	2	WELL #3	A				
1737	INDIAN FIELD WELLFIELD - WELL #4	2	WELL #4	A				
1833	INDIAN FIELD WELLFIELD - WELL #6	2	WELL #6	A				
201	PEAGLER HILL WTP - WELL #1							
202	INDIAN FIELD WELLFIELD WTP							
49343	BRENTWOOD STORAGE TANK							
49345	CANTERBURY STORAGE TANK							
49347	CROSSBROOK STORAGE TANK							
49349	SULLIVAN FARM STORAGE TANK							
49365	CAMELOT HYDROPNEUMATIC STORAGE TANK							
49367	HILL & PLAIN HYDROPNEUMATIC STORAGE TANK							
49369	CROSSBROOK BOOSTER STATION							
49371	HIPP ROAD PUMP STATION							
49373	BRENTWOOD PUMP STATION							
49375	CAMELOT PUMP STATION							
49377	HILL & PLAIN BOOSTER STATION							
49379	M5 BOOSTER STATION							
49381	M1 BOOSTER STATION							
50184	CAMELOT GROUND STORAGE TANK							
530	CAMELOT BOOSTER CHLORINATION							
531	PEAGLER HILL WTP - WELL #2/#3							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name		Classification	Population	Owner Type	Primary Source	
CT0960011	AQUARION WATER CO OF CT-NEW MILFORD		C	7,121	P	GW	
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						3,458	

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
532	CROSSBROOK BOOSTER CHLORINATION							
533	HILL & PLAIN BOOSTER CHLORINATION							
54332	M1 ATMOSPHERIC STORAGE TANK							
54334	M1 HYDROPNEUMATIC STORAGE TANK							
58920	INDIAN FIELD WELLFIELD - WELL #5A	2	INDIAN FIELD-WELL 5A	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LOTT, LESTER	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2021
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
GAGNON, MATTHEW	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021

Water System Facility: **PEAGLER HILL WTP - WELL #1 (WSF ID: 201)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
GAGNON, MATTHEW	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021

Water System Facility: **INDIAN FIELD WELLFIELD WTP (WSF ID: 202)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
GAGNON, MATTHEW	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960011	AQUARION WATER CO OF CT-NEW MILFORD			C	7,121	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						3,458	

Towns Served: NEW MILFORD

Certified Operator Information

Water System Facility: CAMELOT BOOSTER CHLORINATION (WSF ID: 530)

Facility Classification: CLASS 1 TREATMENT PLANT

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
LAGO, ANTHONY V.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019 6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2019 6/30/2021
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021 3/31/2021

Water System Facility: PEAGLER HILL WTP - WELL #2/#3 (WSF ID: 531)

Facility Classification: CLASS 1 TREATMENT PLANT

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
LAGO, ANTHONY V.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019 6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2021 12/31/2019
GAGNON, MATTHEW	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021 3/31/2021

Water System Facility: CROSSBROOK BOOSTER CHLORINATION (WSF ID: 532)

Facility Classification: CLASS 1 TREATMENT PLANT

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
LAGO, ANTHONY V.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019 6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2021 12/31/2019
GAGNON, MATTHEW	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021 3/31/2021

Water System Facility: HILL & PLAIN BOOSTER CHLORINATION (WSF ID: 533)

Facility Classification: CLASS 1 TREATMENT PLANT

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
LAGO, ANTHONY V.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019 6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2021 12/31/2019
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021 3/31/2021

Contact Information

Name	Organization	Job Title
Mr. John P. Walsh	Aquarion Water Company	Vice President
Mailing Address Line One	Mailing Address Line Two	City State Zip Code

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name				Classification	Population	Owner Type	Primary Source		
CT0960011	AQUARION WATER CO OF CT-NEW MILFORD				C	7,121	P	GW		
Local Address (where applicable)				Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
								3,458		
Towns Served: NEW MILFORD										
600 Lindley Street				Mail Stop 250			Bridgeport		CT	06606
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address					
203-337-5852		203-337-5938		781-413-6175	jwalsh@aquarionwater.com					

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960031	SUNNY VALLEY TAX DISTRICT			C	500	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
CALDWELL DRIVE			110	1			
Towns Served: NEW MILFORD							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) **1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21		

Total Coliform (3100) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Lead And Copper (PBCU) **10 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	Complete
	1/1/19 - 12/31/21	6/1-9/30	
	1/1/22 - 12/31/24	6/1-9/30	

Physical Parameters (PPS) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0960031	SUNNY VALLEY TAX DISTRICT			C	500	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
CALDWELL DRIVE				110	1			

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	6/9/2008	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2013	
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION EXEMPTION	3/1/2023	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960031	SUNNY VALLEY TAX DISTRICT			C	500	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
CALDWELL DRIVE			110	1			
Towns Served: NEW MILFORD							

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
E. Coli	9/1/16 - 9/30/16	3	3/10/2018	6/28/2017	3/20/2018	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	1	1 CALDWELL DRIVE	A	Y	3		
		10	10 CALDWELL DRIVE	A	Y	3		
		101	14 DRAPEAU ROAD	A	Y	N		
		1011	15 DRAPEAU ROAD	A	Y	N		
		102	3 HOWE ROAD	A	Y	3		
		103	4 HOWE ROAD	A	Y	3		
		104	5 HOWE ROAD	A	Y	3		
		105	6 HOWE ROAD	A	Y	3		
		106	7 HOWE ROAD	A	Y	3		
		107	8 HOWE ROAD	A	Y	3		
		108	9 HOWE ROAD	A	Y	3		
		109	10 HOWE ROAD	A	Y	3		
		11	11 CALDWELL DRIVE	A	Y	3		
		110	11 HOWE ROAD	A	Y	3		
		111	SUMMIT DRIVE APARTS.	A	Y	3		
		12	15 CALDWELL DRIVE	A	Y	3		
		13	16 CALDWELL DRIVE	A	Y	3		
		14	17 CALDWELL DRIVE	A	Y	3		
		15	18 CALDWELL DRIVE	A	Y	3		
		16	19 CALDWELL DRIVE	A	Y	3		
		17	20 CALDWELL DRIVE	A	Y	3		
		18	21 CALDWELL DRIVE	A	Y	3		
		19	22 CALDWELL DRIVE	A	Y	3		
		2	2 CALDWELL DRIVE	A	Y	3		
		20	23 CALDWELL DRIVE	A	Y	3		
		21	24 CALDWELL DRIVE	A	Y	3		
		22	25 CALDWELL DRIVE	A	Y	3		
		23	26 CALDWELL DRIVE	A	Y	3		
		24	28 CALDWELL DRIVE	A	Y	3		
		25	29 CALDWELL DRIVE	A	Y	3		
		26	30 CALDWELL DRIVE	A	Y	3		
		27	31 CALDWELL DRIVE	A	Y	3		
		27 - 31 CAL	GENERATED BY BATCH	A	Y			
		28	32 CALDWELL DRIVE	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960031	SUNNY VALLEY TAX DISTRICT			C	500	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
CALDWELL DRIVE			110	1			

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		29	33 CALDWELL DRIVE	A	Y	3		
		3	3 CALDWELL DRIVE	A	Y	3		
		30	34 CALDWELL DRIVE	A	Y	3		
		31	36 CALDWELL DRIVE	A	Y	3		
		32	38 CALDWELL DRIVE	A	Y	3		
		33	40 CALDWELL DRIVE	A	Y	3		
		34	42 CALDWELL DRIVE	A	Y	3		
		34 - 42 CAL	GENERATED BY BATCH	A	Y			
		35	44 CALDWELL DRIVE	A	Y	3		
		35 - 44 CAL	GENERATED BY BATCH	A	Y			
		36	46 CALDWELL DRIVE	A	Y	3		
		37	48 CALDWELL DRIVE	A	Y	3		
		38	50 CALDWELL DRIVE	A	Y	3		
		39	2 SHERWOOD DRIVE	A	Y	3		
		4	4 CALDWELL DRIVE	A	Y			
		40	3 SHERWOOD DRIVE	A	Y	3		
		40 - 3 SHER	GENERATED BY BATCH	A	Y			
		41	4 SHERWOOD DRIVE	A	Y	3		
		42	5 SHERWOOD DRIVE	A	Y	3		
		43	6 SHERWOOD DRIVE	A	Y	3		
		44	7 SHERWOOD DRIVE	A	Y	3		
		45	8 SHERWOOD DRIVE	A	Y	3		
		46	9 SHERWOOD DRIVE	A	Y	3		
		47	10 SHERWOOD DRIVE	A	Y	3		
		48	11 SHERWOOD DRIVE	A	Y	3		
		49	13 SHERWOOD DRIVE	A	Y	3		
		5	5 CALDWELL DRIVE	A	Y	3		
		50	14 SHERWOOD DRIVE	A	Y	3		
		51	15 SHERWOOD DRIVE	A	Y	3		
		52	16 SHERWOOD DRIVE	A	Y	3		
		52 - 16 SHE	GENERATED BY BATCH	A	Y			
		53	17 SHERWOOD DRIVE	A	Y	3		
		54	18 SHERWOOD DRIVE	A	Y	3		
		55	19 SHERWOOD DRIVE	A	Y	3		
		56	20 SHERWOOD DRIVE	A	Y	3		
		57	22 SHERWOOD DRIVE	A	Y	3		
		58	23 SHERWOOD DRIVE	A	Y	3		
		59	24 SHERWOOD DRIVE	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960031	SUNNY VALLEY TAX DISTRICT			C	500	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
CALDWELL DRIVE			110	1			

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		6	6 CALDWELL DRIVE	A	Y	3		
		60	25 SHERWOOD DRIVE	A	Y	3		
		61	26 SHERWOOD DRIVE	A	Y	3		
		62	27 SHERWOOD DRIVE	A	Y	3		
		63	28 SHERWOOD DRIVE	A	Y	3		
		64	29 SHERWOOD DRIVE	A	Y	3		
		65	30 SHERWOOD DRIVE	A	Y	3		
		66	31 SHERWOOD DRIVE	A	Y	3		
		67	32 SHERWOOD DRIVE	A	Y	3		
		68	33 SHERWOOD DRIVE	A	Y	3		
		68 - 33 SHE	GENERATED BY BATCH	A	Y			
		69	34 SHERWOOD DRIVE	A	Y	3		
		69 - 34 SHE	GENERATED BY BATCH	A	Y			
		7	7 CALDWELL DRIVE	A	Y	3		
		70	35 SHERWOOD DRIVE	A	Y	3		
		71	36 SHERWOOD DRIVE	A	Y	3		
		72	29 SUNNY VALLEY ROAD	A	Y	3		
		73	35 SUNNY VALLEY ROAD	A	Y	3		
		74	37 SUNNY VALLEY ROAD	A	Y	3		
		75	41 SUNNY VALLEY ROAD	A	Y	3		
		76	43 SUNNY VALLEY ROAD	A	Y	3		
		77	66 SUNNY VALLEY ROAD	A	Y	3		
		78	68 SUNNY VALLEY ROAD	A	Y	3		
		79	69 SUNNY VALLEY ROAD	A	Y	3		
		8	8 CALDWELL DRIVE	A	Y	3		
		80	70 SUNNY VALLEY ROAD	A	Y	3		
		81	72 SUNNY VALLEY ROAD	A	Y	3		
		82	73 SUNNY VALLEY ROAD	A	Y	3		
		83	74 SUNNY VALLEY ROAD	A	Y	3		
		84	76 SUNNY VALLEY ROAD	A	Y	3		
		85	83 SUNNY VALLEY ROAD	A	Y	3		
		86	86 SUNNY VALLEY ROAD	A	Y	3		
		87	88 SUNNY VALLEY ROAD	A	Y	3		
		88	114 FORT HILL ROAD	A	Y	3		
		89	4 SHEPHERD'S PATH	A	Y	3		
		89 - 4 SHEP	GENERATED BY BATCH	A	Y			
		9	9 CALDWELL DRIVE	A	Y	3		
		90	1 MALONEY LANE	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960031	SUNNY VALLEY TAX DISTRICT			C	500	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
CALDWELL DRIVE			110	1			

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		90 - 1 MALO	GENERATED BY BATCH	A	Y			
		91	3 MALONEY LANE	A	Y	3		
		92	4 MALONEY LANE	A	Y	3		
		93	6 MALONEY LANE	A	Y	3		
		93 - 6 MALO	GENERATED BY BATCH	A	Y			
		94	8 MALONEY LANE	A	Y	3		
		95	10 MALONEY LANE	A	Y	3		
		96	2 DRAPEAU ROAD	A	Y	3		
		97	3 DRAPEAU ROAD	A	Y	3		
		98	11 DRAPEAU ROAD	A	Y	3		
		99	12 DRAPEAU ROAD	A	Y	3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1678	WELL 1	2	WELL 1	A				
1679	WELL 2	2	WELL 2	A				
44660	PRESSURE TANK 1							
44662	PRESSURE TANK 2							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
TOMASCAK, THOMAS S.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2021
		WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2019

Contact Information

Name				Organization			Job Title		
Mr. Robert Ginty				Sunny Valley Tax District			Treasurer		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
44 Caldwell Drive						New Milford		CT	06776
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-354-6796						860-354-5561	RobertMGinty@Eaton.com		
Contact Role(s):		Administrative Contact, Legal Contact, Owner							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0960031	SUNNY VALLEY TAX DISTRICT	C	500	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
CALDWELL DRIVE			110	1	
Towns Served: NEW MILFORD					
Name		Organization		Job Title	
Sunny Valley Tax District					
Mailing Address Line One		Mailing Address Line Two		City	State
Emergency Contact				Emergency Contact	CT
					06000
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-355-2800					
Contact Role(s): Owner					

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0960061	BIRCH GROVES ASSOCIATION, INC			C	300	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				75				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/20	6/1-9/30	
	1/1/21 - 12/31/23	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0960061	BIRCH GROVES ASSOCIATION, INC			C	300	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				75				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Gross Beta Particle Activity (4100)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Man-Made Beta Particle & Photon Emitters (4101)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Tritium (4102)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Strontium-90 (4174)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960061	BIRCH GROVES ASSOCIATION, INC			C	300	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			75				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and PCBs-Phase V (SOC5) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		

Organic Chemicals (VOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		BGA001	4MAPLE LN WELL #3	A		N		
		BGA002	SUNSET LN WELL #4	A		N		
		BGA003	OAK POND LN WELL #5	A		N		
		BGA004	18 MAPLE LN	A	Y			
		BGA005	20 MAPLE LN	A	Y	3		
		BGA006	21 MAPLE LN	A	Y	3		
		BGA007	3 ASH LN	A	Y			
		BGA008	5 HICKORY LN	A	Y	3		
		BGA009	9 HICKORY LN	A	Y	3		
		BGA010	1 ELM LN	A	Y	3		
		BGA011	11 ELM LN	A	Y	3		
		BGA012	11 POPLAR LN	A	Y	3		
		BGA013	2 APPLE LN	A	Y			
		BGA014	7 APPLE LN	A	Y			
		BGA015	5 ECHO DRIVE	A	Y			
		BGA016	33 ECHO DRIVE	A	Y			
		BGA017	1 JUNIPER LN	A	Y	N		
		BGA018	6 JUNIPER LN	A	Y	3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0960061	BIRCH GROVES ASSOCIATION, INC			C	300	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				75				

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
1573	MAPLE LANE WELL 3	2	MAPLE LANE 3	A				
1575	SUNSET DRIVE WELL 4	2	SUNSET DRIVE WELL 4	A				
1577	OAK LANE WELL 5	2	OAK LANE WELL 5	A				
44849	STANDPIPE 1							
44851	STANDPIPE 2							
44853	HYDROPNEUMATIC TANK							
44863	SETTLING TANK 1							
44865	SETTLING TANK 2							
44866	TREATMENT PLANT							
53640	BOOSTER STATION							

Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 44866)

Facility Classification:

Operator Name	Operator Type	Certification(s)	Certification Expiration
TOMASCAK, THOMAS S.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2021
		WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2019

Contact Information

Name		Organization			Job Title		
Birch Groves Association, Inc							
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
P. O. Box 484					New Milford	CT	06776
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-354-8613							

Contact Role(s): Owner

Name		Organization			Job Title		
Mr. James Caris		Birch Groves Association, Inc.			Water Comm Chair		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
P.O. Box 484					New Milford	CT	06776
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-733-3032					jamescaris@gmail.com		

Contact Role(s): Administrative Contact, Legal Contact

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960061	BIRCH GROVES ASSOCIATION, INC			C	300	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			75				

Towns Served: **NEW MILFORD**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0960071	CLC OWNERS CORPORATION			C	736	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				177			5	

Towns Served: BROOKFIELD, NEW MILFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) 4 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21		

Total Coliform (3100) 2 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Lead And Copper (PBCU) 10 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/21	6/1-9/30	
	1/1/22 - 12/31/24	6/1-9/30	

Physical Parameters (PPS) 2 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **ENTRY POINT-WELL #2 (WSF ID: 00700)**

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #2 (3)	1/1/17 - 12/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0960071	CLC OWNERS CORPORATION			C	736	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				177			5	

Towns Served: BROOKFIELD, NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT-WELL #2 (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #2 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #2 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #2 (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #2 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #2 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #2 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Water System Facility: ENTRY POINT-WELL #3 (WSF ID: 00701)			
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #3 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #3 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0960071	CLC OWNERS CORPORATION			C	736	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				177			5	

Towns Served: BROOKFIELD, NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT-WELL #3 (WSF ID: 00701)

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #3 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #3 (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #3 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #3 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #3 (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		

Water System Facility: ENTRY POINT-WELL #6 (WSF ID: 00702)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #6 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #6 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #6 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #6 (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0960071	CLC OWNERS CORPORATION			C	736	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				177			5	

Towns Served: BROOKFIELD, NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT-WELL #6 (WSF ID: 00702)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/22 - 12/31/24		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #6 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #6 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #6 (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		

Water System Facility: ENTRY POINT-WELL #9 (WSF ID: 00703)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #9 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #9 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #9 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #9 (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #9 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960071	CLC OWNERS CORPORATION			C	736	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			177			5	

Towns Served: BROOKFIELD, NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT-WELL #9 (WSF ID: 00703)

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT-WELL #9 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT-WELL #9 (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		

Water System Facility: ENTRY POINT-WELLS #8 & #12 (WSF ID: 00704)

Net Gross Alpha (4000)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRYPOINT-WELL8&12 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Uranium (4006)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRYPOINT-WELL8&12 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRYPOINT-WELL8&12 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRYPOINT-WELL8&12 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRYPOINT-WELL8&12 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRYPOINT-WELL8&12 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRYPOINT-WELL8&12 (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0960071	CLC OWNERS CORPORATION			C	736	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				177			5	

Towns Served: BROOKFIELD, NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT-WELLS #8 & #12 (WSF ID: 00704)

Organic Chemicals (VOCS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	7/1/19 - 9/30/19		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2012	
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Organic Chemicals M&R Violation	10/1/03 - 12/31/03	3	4/28/2005		4/28/2005	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		CLC001	83 INDIAN TRAIL	A	Y	3	Y	
		CLC002	15 MOUNTAIN DR	A	Y	3	Y	
		CLC002 - 15	GENERATED BY BATCH	A	Y			
		CLC003	36 INDIAN TRAIL	A	Y	3	Y	
		CLC004	29 INDIAN TRAIL	A	Y	3	Y	
		CLC004 - 29	GENERATED BY BATCH	A	Y			
		CLC005	20 INDIAN TRAIL	A	Y	3	Y	
		CLC005 - 20	GENERATED BY BATCH	A	Y			
		CLC006	1 MEADOW LANE	A	Y	3	Y	
		CLC006 - 1	GENERATED BY BATCH	A	Y			
		CLC007	1 CHIMNEY POINT	A	Y	3	Y	
		CLC008	36 INDIAN TRAIL	A	Y	3	Y	
		CLC009	22 INDIAN TRAIL	A	Y	3	Y	
		CLC010	53 INDIAN TRAIL	A	Y	3	Y	
		CLC010 - 53	GENERATED BY BATCH	A	Y			
		CLC011	27 INDIAN TRAIL	A	Y	3	Y	
		CLC012	3 MEADOW LANE	A	Y	3	Y	
		CLC012 - 3	GENERATED BY BATCH	A	Y			
		CLC013	CLC PRO SHOP	A	Y	3	Y	
		CLC013 - CL	GENERATED BY BATCH	A	Y			
		CLC014	62 INDIAN TRAIL	A	Y	3	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960071	CLC OWNERS CORPORATION			C	736	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			177			5	

Towns Served: BROOKFIELD, NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		CLC014 - 62	GENERATED BY BATCH	A	Y			
		CLC015	2 COTTON TAIL LANE	A	Y	3	Y	
		CLC015 - 2	GENERATED BY BATCH	A	Y			
		CLC016	24 BROOKSIDE TRAIL	A	Y	3	Y	
		CLC017	24 BIRCH LANE	A	Y	3	Y	
		CLC017 - 24	GENERATED BY BATCH	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT-WELL #2	3	ENTRY POINT-WELL #2	A				
00701	ENTRY POINT-WELL #3	3	ENTRY POINT-WELL #3	A				
00702	ENTRY POINT-WELL #6	3	ENTRY POINT-WELL #6	A				
00703	ENTRY POINT-WELL #9	3	ENTRY POINT-WELL #9	A				
00704	ENTRY POINT-WELLS #8 & #12	3	ENTRYPOINT-WELL8&12	A				
1940	WELL 9	2	WELL 9	A				
1960	WELL 12	2	WELL #12	A				
1961	WELL 8	2	WELL #8	A				
324	WELL 3	2	WELL 3	A				
36729	ATMOSPHERIC TANK #1							
586	WELL 2	2	WELL 2	A				
587	WELL 6	2	WELL 6	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMAY, REALE D.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2019 6/30/2020
KILBOURN, ERIC	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019 12/31/2019

Contact Information

Name				Organization			Job Title		
CLC Owners Corporation									
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
Emergency Contact						Emergency Contact		CT	06000
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
860-354-2847									
Contact Role(s):		Owner							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0960071	CLC OWNERS CORPORATION	C	736	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
			177		
					5
Towns Served: BROOKFIELD, NEW MILFORD					
Name		Organization		Job Title	
Mr. Wayne Liscinsky		CLC Owners Corporation		Water Chairman	
Mailing Address Line One		Mailing Address Line Two		City	State
919 Candlewood Lake Rd				Brookfield	CT
					06804
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-354-4004				203-209-7154	4yourwater@gmail.com
Contact Role(s): Administrative Contact, Legal Contact					

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960091	CANDLEWOOD TRAILS ASSOCIATION, INC.			C	312	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			78				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		2 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21		
Total Coliform (3100)		2 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Lead And Copper (PBCU)		5 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/19	6/1-9/30	
	1/1/20 - 12/31/20	6/1-9/30	
Physical Parameters (PPS)		2 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Water System Facility: ENTRY POINT - WELL 5 (WSF ID: 00701)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #5 (3)	1/1/17 - 12/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960091	CANDLEWOOD TRAILS ASSOCIATION, INC.			C	312	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			78				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 5 (WSF ID: 00701)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #5 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per six years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #5 (3)	1/1/14 - 12/31/19		Complete
	1/1/20 - 12/31/25		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #5 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #5 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #5 (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		Complete
	1/1/22 - 12/31/24		

Water System Facility: ENTRY POINT - WELLS 6 & 7 (WSF ID: 00702)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 6 & 7 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 6 & 7 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per six years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 6 & 7 (3)	1/1/16 - 12/31/21		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960091	CANDLEWOOD TRAILS ASSOCIATION, INC.			C	312	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			78				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT - WELLS 6 & 7 (WSF ID: 00702)

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 6 & 7 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 6 & 7 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2011	
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	04C - 4 CLU	GENERATED BY BATCH	A	Y			
		18S	18 SPRING LANE	A				Y
		24B	24 BEACH DRIVE	A	Y	1		
		26B	26 BEACH DRIVE	A				Y
		26B - 26 BE	GENERATED BY BATCH	A	Y			
		4	DISTRIBUTION SYSTEM	A	Y			
		47L - 47 LA	GENERATED BY BATCH	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		DP5	CLUBHOUSE	A	Y			
		DP5 - CLUBH	GENERATED BY BATCH	A	Y			
		DP67	5 CEDAR DRIVE	A	Y			
		DP67 - 5 CE	GENERATED BY BATCH	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	ENTRY POINT - WELL 5	3	ENTRY POINT-WELL #5	A				
00702	ENTRY POINT - WELLS 6 & 7	3	EP - WELLS 6 & 7	A				
345	WELL 5	2	WELL 5	A				
45496	WELL 5 PRESSURE TANK							
55217	WELL 6	2	WELL 6	A				
55221	WELL 7	2	WELL 7	A				
58822	WELLS 6 & 7 BLADDER TANKS							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960091	CANDLEWOOD TRAILS ASSOCIATION, INC.			C	312	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			78				

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
58825	WELLS 6 & 7 PUMP STATION							
58827	WELLS 6 & 7 ATMOSPHERIC TANK							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: DISTRIBUTION SYSTEM

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
TOMASCAK, THOMAS S.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2021
		WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2019

Contact Information

Name				Organization			Job Title		
Mr. Ken Schmalz				Candlewood Trails Assn, Inc.			President		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
39 Lake Drive						New Milford		CT	06776
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
973-766-2439						860-799-6380	kschmalz@sa-eventservices.com		

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960101	AQUARION WATER CO OF CT-CARMEN HILL			C	322	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			123				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (0999)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
23 POLARIS DRIVE SS-CH (04549)	1/1/18 - 12/31/18	8/1-8/31	Complete
	1/1/19 - 12/31/19	8/1-8/31	
	1/1/20 - 12/31/20	8/1-8/31	
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/20	6/1-9/30	
	1/1/21 - 12/31/23	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name		Classification	Population	Owner Type	Primary Source	
CT0960101	AQUARION WATER CO OF CT-CARMEN HILL		C	322	P	GW	
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			123				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Water System Facility: ENTRY POINT (WSF ID: 00700)

Gross Beta Particle Activity (4100)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			

Man-Made Beta Particle & Photon Emitters (4101)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			

Tritium (4102)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			

Strontium-90 (4174)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			

Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/16 - 12/31/18		Complete	
	1/1/19 - 12/31/21			
	1/1/22 - 12/31/24			

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete	
	1/1/19 - 12/31/19		Complete	
	1/1/20 - 12/31/20			

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete	
	1/1/19 - 3/31/19		Complete	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960101	AQUARION WATER CO OF CT-CARMEN HILL			C	322	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			123				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.25 MG/L	Continuous
Start Date: 4/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Lead and Copper M&R Violation	1/1/15 - 12/31/17	3	1/10/2019		1/20/2019	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	04549	23 POLARIS DRIVE SS-	A	Y	Y	Y
		4	DISTRIBUTION SYSTEM	A	Y		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960101	AQUARION WATER CO OF CT-CARMEN HILL			C	322	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			123				

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		CHO-001	11 FOREST DRIVE	A	Y	1	Y	
		CHO-002	1 GRETLE LANE	A	Y	3		
		CHO-003	12 GRETLE LANE	A	Y	1		
		CHO-004	6 GRETLE LAND	A	Y	3		
		CHO-005	3 FOREST DRIVE	A	Y	3	Y	
		CHO-006	204 CARMEN HILL #2	A	Y	3		
		CHO-007	155 CARMEN HILL #2	A	Y	3		
		CHO-008	74 CARMEN HILL #1	A	Y	1		
		CHO-009	17 POLARIS DRIVE	A	Y	3		
		CHO-010	24 OVERLOOK DRIVE	A	Y	3		
		CHO-011	20 WARWICK DRIVE	A	Y	3		
		CHO-012	22 OVERLOOK DRIVE	A	Y	3		
		CHO-013	67 MIST HILL DRIVE	A	Y	3		
		CHO-014	4 DAILEY ROAD	A	Y	3		
		CHO-015	41 OVERLOOK DRIVE	A	Y	1		
		CHO-016	42 OVERLOOK DRIVE	A	Y	3		
		CHO-017	1 OVERLOOK DRIVE	A	Y	3		
		CHO-018	32 OVERLOOK DRIVE	A	Y	3		
		CHO-019	17 POLARIS DRIVE	A	Y	3		
		CHO-020	157 CARMEN HILL #2	A	Y	3		
		CHO-021	9 GRETLE LANE	A	Y	3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB7329	28 OVERLOOK DR.	A	Y	3		
		PB7330	1 GRETLE LN.	A	Y	3		
		PB7331	2 GRETLE LN.	A	Y	3		
		PB7332	6 GRETLE LN.	A	Y	3		
		PB7333	3 FOREST DR.	A	Y	3		
		PB7369	26 OVERLOOK DR.	A	Y	3		
		PB8071	74 CARMEN HILL RD.	A	Y	1		
		PB8315	4 POLARIS DR	A	Y	3		
		PB8316	1 OVERLOOK DR	A	Y	3		
		PB8317	10 OVERLOOK DR	A	Y	3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1570	WELL 1	2	WELL 1	A				
1571	WELL 3	2	WELL 3	A				
1572	WELL 4	2	WELL 4	A				
319	WELL 2	2	WELL 2	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name		Classification	Population	Owner Type	Primary Source	
CT0960101	AQUARION WATER CO OF CT-CARMEN HILL		C	322	P	GW	
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			123				

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
544	CARMEN HILL PUMPHOUSE							
60195	CARMEN HILL BOOSTER PS							
60570	ATMOSPHERIC TANKS							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021

Water System Facility: **CARMEN HILL PUMPHOUSE (WSF ID: 544)**

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021

Contact Information

Name				Organization		Job Title		
Mr. John P. Walsh				Aquarion Water Company		Vice President		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
600 Lindley Street			Mail Stop 250			Bridgeport	CT	06606
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-337-5852		203-337-5938		781-413-6175	jwalsh@aquarionwater.com			

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960141	AQUARION WATER CO OF CT-FOREST HILLS SYS			C	265	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			101				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (0999)		2 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
Asbestos (1094)		2 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21		
Total Coliform (3100)		2 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
20 MAPLE DRIVE (04572)	1/1/18 - 12/31/18	8/1-8/31	Complete
	1/1/19 - 12/31/19	8/1-8/31	
	1/1/20 - 12/31/20	8/1-8/31	
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/21	6/1-9/30	
	1/1/22 - 12/31/24	6/1-9/30	
Physical Parameters (PPS)		2 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960141	AQUARION WATER CO OF CT-FOREST HILLS SYS			C	265	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			101				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)		2 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: ENTRY POINT-WELL #2 (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #2 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #2 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #2 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #2 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #2 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #2 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #2 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960141	AQUARION WATER CO OF CT-FOREST HILLS SYS			C	265	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			101				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT-WELL #2 (WSF ID: 00700)

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/20		

Water System Facility: ENTRY POINT-WELL #4 (WSF ID: 00701)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #4 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #4 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #4 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #4 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #4 (3)	1/1/18 - 12/31/18		
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #4 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #4 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Water System Facility: ENTRY POINT-WELL #1A (WSF ID: 00702)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960141	AQUARION WATER CO OF CT-FOREST HILLS SYS			C	265	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			101				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT-WELL #1A (WSF ID: 00702)

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA) 1 routine (RT) per six years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/14 - 12/31/19		Complete
	1/1/20 - 12/31/25		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Water System Facility: WELL 4 (WSF ID: 1756)

E. Coli (3014) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 4 (2)	10/1/18 - 12/31/18		Out of Service
	1/1/19 - 3/31/19		
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: WELL 2 (WSF ID: 323)

E. Coli (3014) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: WELL 1A (WSF ID: 53632)

E. Coli (3014) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1A (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960141	AQUARION WATER CO OF CT-FOREST HILLS SYS			C	265	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			101				

Towns Served: NEW MILFORD

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT-WELL #2 (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 12/1/2008	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		

Water System Facility: **ENTRY POINT-WELL #4 (WSFID: 00701)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 12/1/2008	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		

Water System Facility: **ENTRY POINT-WELL #1A (WSFID: 00702)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 12/1/2008	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0960141	AQUARION WATER CO OF CT-FOREST HILLS SYS			C	265	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				101				

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	04572	20 MAPLE DRIVE	A	Y	3	Y	Y
		04573	2 MILESTONE RIDGE SS	A	Y			
		04574	FOREST HILLS TANK PS	A	Y			
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		FH0001	8 MILLSTONE RIDGE RD	A	Y		Y	
		FH0002	10 MILLSTONE RDG RD	A	Y	3		
		FH0003	33 MAPLE DRIVE	A	Y	3		
		FH0004	34 MAPLE DRIVE	A	Y	3		
		FH0005	151 CW LAKE ROAD	A	Y	3		
		FH0006	155 CW LAKE ROAD	A	Y	3		
		FH0007	160 CW LAKE ROAD	A	Y	1		
		FH0008	162 CW LAKE ROAD	A	Y	3		
		FH0009	184 CW LAKE ROAD	A	Y	3		
		FH0010	190 CW LAKE ROAD	A	Y	3		
		FH0011	192 CW LAKE ROAD	A	Y	3		
		FH0012	194 CW LAKE ROAD	A	Y	3		
		FH0013	196 CW LAKE ROAD	A	Y	3		
		FH0014	200 CW LAKE ROAD	A	Y	1		
		FH0015	201 CW LAKE ROAD	A	Y	3		
		FH0016	202 CW LAKE ROAD	A	Y	3		
		FH0017	156 CW LAKE ROAD	A	Y	3		
		FH0018	158 CW LAKE ROAD	A	Y	3		
		FH0019	167 CW LAKE ROAD	A	Y	3		
		FH0020	180 CW LAKE ROAD	A	Y	3		
		FH0021	3 FIR DRIVE	I	Y			
		FH0022	4 FIR DRIVE	A	Y	3		
		FH0023	6 FIR DRIVE	A	Y	3		
		FH0024	17 LAKEVIEW ROAD	A	Y	3		
		FH0025	11 LAKEVIEW ROAD	A	Y	3		
		FH0026	9 LAKEVIEW ROAD	A	Y	3		
		FH0027	7 LAKEVIEW ROAD	I	Y	3		
		FH0028	5 LAKEVIEW ROAD	A	Y	3		
		FH0029	3 LAKEVIEW ROAD	A	Y	3		
		FH0030	1 LAKEVIEW ROAD	A	Y	1		
		FH0031	15 LAKEVIEW ROAD	A	Y	3		
		FH0032	12 LAUREL ROAD	I	Y	3		
		FH0033	10 LAUREL DRIVE	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960141	AQUARION WATER CO OF CT-FOREST HILLS SYS			C	265	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			101				

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		FH0034	9 LAUREL DRIVE	A	Y	3	Y	
		FH0035	7 LAUREL DRIVE	A	Y	1		
		FH0036	14 LAUREL DRIVE	A	Y	3		
		FH0037	11 LAUREL DRIVE	A	Y	1		
		FH0038	8 LAUREL DRIVE	A	Y	3		
		FH0039	5 LAUREL DRIVE	I	Y	3		
		FH0040	4 LAUREL DRIVE	A	Y	3		
		FH0041	3 LAUREL DRIVE	A	Y	3		
		FH0042	2 LAUREL DRIVE	A	Y	3		
		FH0043	1 LAUREL DRIVE	A	Y	3		
		FH0044	46 MAPLE DRIVE	A	Y	3	Y	
		FH0045	44 MAPLE DRIVE	A	Y	3		
		FH0046	43 MAPLE DRIVE	A	Y	3		
		FH0047	38 MAPLE DRIVE	A	Y	3		
		FH0048	37 MAPLE DRIVE	A	Y	3		
		FH0049	36 MAPLE DRIVE	A	Y	3		
		FH0050	35 MAPLE DRIVE	I	Y	3		
		FH0051	32 MAPLE DRIVE	I	Y	3		
		FH0052	30 MAPLE DRIVE	A	Y	3		
		FH0053	28 MAPLE DRIVE	I	Y	3		
		FH0054	26 MAPLE DRIVE	I	Y	3		
		FH0055	25 MAPLE DRIVE	A	Y	3		
		FH0056	24 MAPLE DRIVE	A	Y	3		
		FH0057	22 MAPLE DRIVE	I	Y	3		
		FH0059	18 MAPLE DRIVE	I	Y	3		
		FH0060	14 MAPLE DRIVE	A	Y	3		
		FH0061	11 MAPLE DRIVE	A	Y	3		
		FH0062	10 MAPLE DRIVE	A	Y	3		
		FH0063	4 MAPLE DRIVE	A	Y	3		
		FH0064	2 MAPLE DRIVE	A	Y	3		
		FH0065	19 MILLSTONE HILL	A	Y	1		
		FH0066	11 MILLSTONE HILL	I	Y			
		FH0067	8 MILLSTONE HILL	A	Y	3		
		FH0068	4 MILLSTONE HILL	A	Y	3		
		FH0069	3 MILLSTONE HILL	I	Y	3		
		FH0070	25 MILLSTONE RIDGE	I	Y			
		FH0071	21 MILLSTONE RIDGE	A	Y	3		
		FH0072	15 MILLSTONE RIDGE	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960141	AQUARION WATER CO OF CT-FOREST HILLS SYS			C	265	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			101				

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		FH0073	3 MILLSTONE RIDGE	A	Y	3		
		FH0074	29 OAK ROAD	A	Y	3		
		FH0075	25 OAK ROAD	I	Y	3		
		FH0076	24 OAK ROAD	A	Y	1		
		FH0077	21 OAK ROAD	A	Y	3		
		FH0078	20 OAK ROAD	A	Y	3		
		FH0079	19 OAK ROAD	A	Y	3		
		FH0080	18 OAK ROAD	A	Y	3		
		FH0081	15 OAK ROAD	A	Y	3	Y	
		FH0082	12 OAK ROAD	A	Y	3		
		FH0083	11 OAK ROAD	A	Y	3		
		FH0084	10 OAK ROAD	A	Y	3		
		FH0085	9 OAK ROAD	A	Y	3		
		FH0086	7 OAK ROAD	A	Y	3		
		FH0087	5 OAK ROAD	A	Y	3		
		FH0088	3 OAK ROAD	A	Y	3		
		FH0089	1 OAK ROAD	I	Y	3		
		FH0090	40 MAPLE DRIVE	A	Y	3		
		FH0091	31 MAPLE DRIVE	A	Y	3		
		FH0092	27 MAPLE DRIVE	A	Y	3		
		FH0093	16 MAPLE DRIVE	A	Y	3		
		FH0094	17 MILLSTONE RIDGE	A	Y	3		
		FH0095	4 MILLSTONE RIDGE	A	Y	3		
		FH0096	17 OAK ROAD	A	Y	3		
		FH0097	16 OAK ROAD	A	Y	3		
		FH0098	4 OAK ROAD	A	Y	3		
		FH0099	12 MILLSTONE RIDGE	A	Y	3		
		FH0100	29 MAPLE DRIVE	A	Y	3		
		FH0101	21 MILLSTONE HILL	A	Y	3		
		FH08087	5 OAK ROAD	A	Y	3		
		PB7423	PB7423 - 38 MAPLE DR	A		3		
		PB7424	PB7424 - 192 CANDLEW	A		3		
		PB7425	PB7425 - 4 MILLSTONE	A		3		
		PB7426	PB7426 - 46 MAPLE DR	A		3		
		PB7427	PB7427 - 7 LAUREL DR	A		N		
		PB8377	6 FIR DRIVE	A		1		
		PB8378	4 MILLSTONE HILL RD	A		3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960141	AQUARION WATER CO OF CT-FOREST HILLS SYS			C	265	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			101				

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00700	ENTRY POINT-WELL #2	3	ENTRY POINT-WELL #2	A				
00701	ENTRY POINT-WELL #4	3	ENTRY POINT-WELL #4	A				
00702	ENTRY POINT-WELL #1A	3	EP - WELL 1A	A				
1756	WELL 4	2	WELL 4	A				
323	WELL 2	2	WELL 2	A				
53632	WELL 1A	2	WELL 1A	A				
55615	WELL #1A TREATMENT PLANT							
55617	WELL #2 TREATMENT PLANT							
55619	WELL #4 TREATMENT PLANT							
56207	ATMOSPHERIC STORAGE TANKS (2)							
56209	BOOSTER PUMPS							
56211	WELL #5 TREATMENT PLANT	3	WELL #5 TREATMENT PL	A				
56288	WELL 5	2	WELL 5	A				
60199	WELL # 2 HYDROPNEUMATIC TANK							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification:

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019 6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2019 6/30/2021
GAGNON, MATTHEW	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021 3/31/2021

Water System Facility: **WELL #1A TREATMENT PLANT (WSF ID: 55615)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019 6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2021 12/31/2019
GAGNON, MATTHEW	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021 3/31/2021

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960141	AQUARION WATER CO OF CT-FOREST HILLS SYS			C	265	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			101				

Towns Served: NEW MILFORD

Certified Operator Information

Water System Facility: **WELL #2 TREATMENT PLANT (WSF ID: 55617)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
GAGNON, MATTHEW	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021

Water System Facility: **WELL #4 TREATMENT PLANT (WSF ID: 55619)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
GAGNON, MATTHEW	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021

Water System Facility: **WELL #5 TREATMENT PLANT (WSF ID: 56211)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021

Contact Information

Name				Organization		Job Title		
Mr. John P. Walsh				Aquarion Water Company		Vice President		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
600 Lindley Street			Mail Stop 250			Bridgeport	CT	06606
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-337-5852		203-337-5938		781-413-6175	jwalsh@aquarionwater.com			
Contact Role(s):	Administrative Contact, Legal Contact							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960141	AQUARION WATER CO OF CT-FOREST HILLS SYS			C	265	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			101				

Towns Served: **NEW MILFORD**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960151	CANDLE HILL MOBILE HOME PARK			C	233	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			93				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21		
Total Haloacetic Acids (2456)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
4 BALTIC LANE (4-B)	1/1/18 - 12/31/18	8/1-8/31	Complete
	1/1/19 - 12/31/19	8/1-8/31	
	1/1/20 - 12/31/20	8/1-8/31	
Total Trihalomethanes (2950)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
21 DUNCAN LANE (21-D)	1/1/18 - 12/31/18	8/1-8/31	Complete
	1/1/19 - 12/31/19	8/1-8/31	
	1/1/20 - 12/31/20	8/1-8/31	
Total Coliform (3100)		2 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/21	6/1-9/30	
	1/1/22 - 12/31/24	6/1-9/30	
Physical Parameters (PPS)		2 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960151	CANDLE HILL MOBILE HOME PARK			C	233	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			93				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)		2 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Water System Facility: ENTRY POINT (WSF ID: 00700)

Chloride (1017)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete	
	1/1/19 - 3/31/19		Complete	
	4/1/19 - 6/30/19			
	7/1/19 - 9/30/19			

Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/16 - 12/31/18		Complete	
	1/1/19 - 12/31/21			
	1/1/22 - 12/31/24			

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete	
	1/1/19 - 12/31/19			
	1/1/20 - 12/31/20			

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/18 - 12/31/20			
	1/1/21 - 12/31/23			

Organic Chemicals (VOCS)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete	
	1/1/19 - 12/31/19		Complete	
	1/1/20 - 12/31/20			

Water System Facility: WELL 1 (WSF ID: 320)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960151	CANDLE HILL MOBILE HOME PARK			C	233	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			93				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: WELL 1 (WSF ID: 320)

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2016	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
STAGE 2 DBPR - SUBMIT MONITORING PLAN	2/5/2016	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2018	
CROSS CONNECTION SURVEY REPORT	3/1/2019	
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Chloride M&R Violation	7/1/18 - 9/30/18	3	1/4/2020	1/16/2019	1/14/2020	1/16/2019

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960151	CANDLE HILL MOBILE HOME PARK			C	233	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			93				

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	10-C	10 CANDLEWOOD RD	I	Y	N		
		10-T	10 TALLOW LANE	A	Y	N		
		11-W	11 WICKER LANE	A	Y	N		
		13-D	13 DUNCAN LANE	A	Y	3		
		14-C	14 CANDLEWOOD ROAD	A		3		
		14-S	14 SHADOW LANE	A		3		
		14-S - 14 S	GENERATED BY BATCH	A	Y			
		14-T	14 TALLOW LANE	A	Y	3		
		21-D	21 DUNCAN LANE	A	Y	N	Y	Y
		24-V	24 VICTORY LANE	A		3		
		24-V - 24 V	GENERATED BY BATCH	A	Y			
		2-B	2 BALTIC LANE	I	Y	N		
		2-E	2 EDEN LANE	A		3		
		2-T	2 TALLOW LANE	A	Y	3		
		2-T - 2 TAL	GENERATED BY BATCH	A	Y			
		3-D	3 DUNCAN LANE	I	Y			
		4	GENERIC DISTRIBUTION	A	Y			
		4-B	4 BALTIC LANE	A		N		Y
		5-B	5 BALTIC LANE	A		3		
		5-T	5 TALLOW LANE	A	Y	3		
		6-C	6 CANDLE WOOD RD	A	Y	3		
		6-E	6 EDEN LANE	A	Y	3		
		6-W	6 WICKER LANE	A		3		
		6-W - 6 WIC	GENERATED BY BATCH	A	Y			
		7-D	7 DUNCAN LANE	A	Y	3		
		9-V	9 VICTORY LANE	A		3		
		9-V - 9 VIC	GENERATED BY BATCH	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
320	WELL 1	2	WELL 1	A				
50644	CONTACT TANKS							
599	CANDLE HILL MHP TREATMENT PLANT							
59950	PUMP STATION							
59952	ATMOSPHERIC TANK							
59954	BLADDER TANKS							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960151	CANDLE HILL MOBILE HOME PARK			C	233	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			93				

Towns Served: NEW MILFORD

Certified Operator Information

Water System Facility: **CANDLE HILL MHP TREATMENT PLANT (WSF ID: 599)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HURLBUT, ANDREW	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2020

Contact Information

Name				Organization		Job Title			
Mr. Richard K. Freedman				Garden Homes Management Corp.		President			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
29 Knapp Street						Stamford		CT	06907
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-348-2200		2475	203-967-8372			203-219-1971	richard@gardenhomesmanagement.com		

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960161	AQUARION WATER CO OF CT-DEAN HEIGHTS SYS			C	162	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			62				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (0999)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
26 DEAN ROAD SS-DH (04630)	1/1/18 - 12/31/18	7/1-7/31	Complete
	1/1/19 - 12/31/19	7/1-7/31	
	1/1/20 - 12/31/20	7/1-7/31	
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	
	1/1/20 - 12/31/22	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960161	AQUARION WATER CO OF CT-DEAN HEIGHTS SYS			C	162	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			62				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			

Uranium (4006)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			

Combined Radium-226/228 (4010)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			

Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/16 - 12/31/18		Complete	
	1/1/19 - 12/31/21			
	1/1/22 - 12/31/24			

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete	
	1/1/19 - 12/31/19		Complete	
	1/1/20 - 12/31/20			

Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/18 - 12/31/20			
	1/1/21 - 12/31/23			

Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/18 - 12/31/20			
	1/1/21 - 12/31/23			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960161	AQUARION WATER CO OF CT-DEAN HEIGHTS SYS			C	162	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			62				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point RDC (EPRD)	Minimum: 1.0 MG/L	Continuous	
Start Date: 4/1/2017				
Compliance History:		Operating Limit	Monitoring	
Monitoring Period		Compliance Status:	Compliance Status:	
11/1/2018 - 11/30/2018		Y		Y
12/1/2018 - 12/31/2018		Y		Y
1/1/2019 - 1/31/2019		Y		Y
2/1/2019 - 2/28/2019		Y		Y
3/1/2019 - 3/31/2019		Y		Y
4/1/2019 - 4/30/2019				

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7 PH	4	
Start Date: 12/1/2013				
Compliance History:		Operating Limit	Monitoring	
Monitoring Period		Compliance Status:	Compliance Status:	
11/1/2018 - 11/30/2018				N
12/1/2018 - 12/31/2018				N
1/1/2019 - 1/31/2019				N
2/1/2019 - 2/28/2019				N
3/1/2019 - 3/31/2019				
4/1/2019 - 4/30/2019				

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2012	
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	04629	57 DEAN ROAD SS-DH	A	Y			
		04630	26 DEAN ROAD SS-DH	A	Y		Y	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960161	AQUARION WATER CO OF CT-DEAN HEIGHTS SYS			C	162	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			62				

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		4	DISTRIBUTION SYSTEM	A	Y			
		DH-10	61 DEAN ROAD	A	Y	3		
		DH-12	65 DEAN ROAD	A	Y	3		
		DH-13	69 DEAN ROAD	A	Y	3		
		DH-14	72 DEAN ROAD	A	Y	3		
		DH-2	50 DEAN ROAD	A	Y	3	Y	
		DH-3	4 DEAN ROAD	A	Y	3		
		DH-4	18 DEAN ROAD	A	Y	3		
		DH-6	29 DEAN ROAD	A	Y	3		
		DH-7	31 DEAN ROAD	A	Y	3		
		DH-8	34 DEAN ROAD	A	Y	3		
		DH-9	36 DEAN ROAD	A	Y	3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB7120	29 DEAN RD	A	Y	3		
		PB7121	66 DEAN RD	A	Y	3		
		PB7122	25 DEAN RD	A	Y	3		
		PB7123	51 DEAN RD	A	Y	3		
		PB7124	63 DEAN RD	A	Y	3		
		PB7125	28 DEAN RD	A	Y	3		
		PB7126	14 DEAN RD	A	Y	3		
		PB7127	9 DEAN RD	A	Y	3		
		PB7128	59 DEAN RD	A	Y	3		
		PB7129	55 DEAN RD	A	Y	3		
		PB7130	8 DEAN RD	A	Y	1		
		PB7131	22 DORWIN HILL RD	A	Y	3		
		PB7133	19 DEAN RD	A	Y	3		
		PB7176	11 DEAN RD	A	Y	3		
		PB7905	16 DORWIN HILL RD	A		3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
355	WELL 1	2	WELL 1	A				
361	WELL 4	2	WELL 4	A				
362	WELL 3	2	WELL 3	A				
45572	ATMOSPHERIC TANK 1 - EAST							
45574	ATMOSPHERIC TANK 2 - WEST							
541	TREATMENT PLANT							
60197	BOOSTER PUMP STATION							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960161	AQUARION WATER CO OF CT-DEAN HEIGHTS SYS			C	162	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			62				

Towns Served: NEW MILFORD

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
GAGNON, MATTHEW	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021

Water System Facility: **TREATMENT PLANT (WSF ID: 541)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021

Contact Information

Name		Organization		Job Title		
Mr. John P. Walsh		Aquarion Water Company		Vice President		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
600 Lindley Street		Mail Stop 250		Bridgeport	CT	06606
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-337-5852		203-337-5938		781-413-6175	jwalsh@aquarionwater.com	

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960171	LILLINONAH PARK ESTATES HOMEOWNERS ASSN			C	128	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			32				

Towns Served: BROOKFIELD, NEW MILFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
27 GREEN VIEW ROAD (LLPE022)	1/1/11 - 12/31/19		
	1/1/20 - 12/31/28		

Total Coliform (3100) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Lead And Copper (PBCU) 5 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/21	6/1-9/30	
	1/1/22 - 12/31/24	6/1-9/30	

Physical Parameters (PPS) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
---	--------------------------	--------------------------	--------------------------

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960171	LILLINONAH PARK ESTATES HOMEOWNERS ASSN			C	128	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			32				

Towns Served: BROOKFIELD, NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
RESPOND TO SANITARY SURVEY	5/30/2009	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2012	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2018	
CROSS CONNECTION SURVEY REPORT	3/1/2019	
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	

Water System Facility and Sampling Point Inventory

Water System	Water System Facility	Sampling Point	Sampling Point	Total Coliform	Lead and Copper	Stage
--------------	-----------------------	----------------	----------------	----------------	-----------------	-------

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0960171	LILLINONAH PARK ESTATES HOMEOWNERS ASSN			C	128	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				32				

Towns Served: BROOKFIELD, NEW MILFORD

Facility ID	ID	Description	Status	Rule	Rule Tier	Asbestos	WQP 2 DBPR
00600 DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM WITHIN 5 SERVICE CON	A				
	LLPE001	1 GREEN VIEW ROAD	A	Y	3		
	LLPE002	2 GREEN VIEW ROAD	A	Y	3		
	LLPE003	3 GREEN VIEW ROAD	A	Y	N		
	LLPE003 - 3	GENERATED BY BATCH	A	Y			
	LLPE004	4 GREEN VIEW ROAD	A	Y	3		
	LLPE005	5 GREEN VIEW ROAD	A	Y	N		
	LLPE005 - 5	GENERATED BY BATCH	A	Y			
	LLPE006	7 GREEN VIEW ROAD	A	Y	3		
	LLPE007	9 GREEN VIEW ROAD	A	Y	3		
	LLPE008	10 GREEN VIEW ROAD	A	Y	3		
	LLPE009	11 GREEN VIEW ROAD	A	Y	3		
	LLPE010	15 GREEN VIEW ROAD	A	Y	3		
	LLPE010 - 1	GENERATED BY BATCH	A	Y			
	LLPE011	16 GREEN VIEW ROAD	A	Y	3		
	LLPE012	17 GREEN VIEW ROAD	A	Y	3		
	LLPE013	18 GREEN VIEW ROAD	A	Y	3		
	LLPE014	19 GREEN VIEW ROAD	A	Y	3		
	LLPE015	20 GREEN VIEW ROAD	A	Y	3		
	LLPE016	21 GREEN VIEW ROAD	A	Y	3		
	LLPE017	22 GREEN VIEW ROAD	A	Y	3		
	LLPE018	23 GREEN VIEW ROAD	A	Y	3		
	LLPE019	24 GREEN VIEW ROAD	A	Y	3		
	LLPE019 - 2	GENERATED BY BATCH	A	Y			
	LLPE020	25 GREEN VIEW ROAD	A	Y	3		
	LLPE021	26 GREEN VIEW ROAD	A	Y	3		
	LLPE022	27 GREEN VIEW ROAD	A	Y	3	Y	
	LLPE023	29 GREEN VIEW ROAD	A	Y	N		
	LLPE024	31 GREEN VIEW ROAD	A	Y	3		
	LLPE025	33 GREEN VIEW ROAD	A	Y	N		
	LLPE025 - 3	GENERATED BY BATCH	A	Y			
	LLPE026	35 GREEN VIEW ROAD	A	Y	3		
	LLPE027	16 LAUREL STREET	A	Y	3		
	LLPE028	52 OLD BRIDGE ROAD	A	Y	3		
	LLPE029	6 NEW BRIDGE ROAD	A	Y	3		
	LLPE030	9 IDAWAY	A	Y	3		
	LLPE031	1 RUSTIC HILL LANE	A	Y	3		
	LLPE032	2 RUSTIC HILL LANE	A	Y	N		
	LLPE033	14 GREEN VIEW ROAD	A	Y	N		
		UPSTREAM WITHIN 5 SERVICE CON	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960171	LILLINONAH PARK ESTATES HOMEOWNERS ASSN			C	128	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			32				

Towns Served: BROOKFIELD, NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00700	ENTRY POINT	3	ENTRY POINT	A				
1685	WELL 2	2	WELL 2	A				
358	WELL 1	2	WELL 1	A				
430	PARALLEL IRON FILTERS (GAC-BIRM)							
52190	ATMOSPHERIC STORAGE							
52192	PRESSURE STORAGE							
58195	BOOSTER PUMPS							

Certified Operator Information

Water System Facility: **PARALLEL IRON FILTERS (GAC-BIRM) (WSF ID: 430)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
FOLEY, JAMES	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2020

Contact Information

Name				Organization		Job Title			
Mr. David Abbondonolo				Lillinonah Park Estates Ha		Board President			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
2 Stony Hill Rd			Suite 201			Bethel		CT	06801
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
203-790-6888	689	230-790-9390		203-790-6888					

Contact Role(s): **Legal Contact**

Name				Organization		Job Title			
Mr. Jason R. Keller				Scalzo Property Management Inc		Property Manager			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
2 Stony Hill Road, Suite 201						Bethel		CT	06801
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-790-6888		689	203-790-9390			203-290-6888	jkeller@scalzoproperty.com		

Contact Role(s): **Administrative Contact**

Please note the following:

- The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
- If a Collection Period is specified, all water quality samples must be collected during the specified period.
- Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960191	OLD FARMS CONDOMINIUM ASSOCIATION INC			C	285	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			95				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (0999)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
UNIT 116 (OFCA003)	1/1/18 - 12/31/18	7/1-7/31	Complete
	1/1/19 - 12/31/19	7/1-7/31	
	1/1/20 - 12/31/20	7/1-7/31	
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/21	6/1-9/30	
	1/1/22 - 12/31/24	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960191	OLD FARMS CONDOMINIUM ASSOCIATION INC			C	285	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			95				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	3/1/19 - 3/31/19		Complete	
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960191	OLD FARMS CONDOMINIUM ASSOCIATION INC			C	285	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			95				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily	
Start Date: 4/1/2017	Compliance History:	Operating Limit	Monitoring	
	Monitoring Period	Compliance Status:	Compliance Status:	
	11/1/2018 - 11/30/2018	Y	Y	
	12/1/2018 - 12/31/2018	Y	Y	
	1/1/2019 - 1/31/2019	Y	Y	
	2/1/2019 - 2/28/2019	Y	Y	
	3/1/2019 - 3/31/2019	Y	Y	
	4/1/2019 - 4/30/2019			

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
STAGE 2 DBPR - SUBMIT MONITORING PLAN	10/1/2013	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2018	
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Chlorine M&R Violation	3/1/11 - 3/31/11	3	9/6/2013		9/16/2013	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		OFCA001	UNIT 72	A	Y		
		OFCA001 - U	GENERATED BY BATCH	A	Y		
		OFCA002	UNIT 27	A	Y	3	
		OFCA002 - U	GENERATED BY BATCH	A	Y		
		OFCA003	UNIT 116	A		3	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960191	OLD FARMS CONDOMINIUM ASSOCIATION INC			C	285	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			95				

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		OFC004	UNIT 74	A		3		
		OFC004 - U	GENERATED BY BATCH	A	Y			
		OFC005	UNIT88	A		3		
		OFC005 - U	GENERATED BY BATCH	A	Y			
		OFC006	UNIT16	A		3		
		OFC006 - U	GENERATED BY BATCH	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1840	WELL 5	2	WELL 5	A				
351	WELL 2	2	WELL 2	A				
352	WELL 3	2	WELL 3	A				
359	WELL 4	2	WELL 4	A				
37768	ATMOSPHERIC TANK							
59973	OLD FARMS PUMP STATION							
59988	BLADDER TANKS							
623	PUMP HOUSE							

Certified Operator Information

Water System Facility: PUMP HOUSE (WSF ID: 623)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
TOMASCAK, THOMAS S.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2021
		WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2019

Contact Information

Name				Organization			Job Title		
Ms. Lisa A Giannone				49 Old Farms Condo			Owner		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
49 Old Farms Lane						New Milford		CT	06776
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
860-354-9234							lisa_ann_giannone@sbcglobal.net		

Contact Role(s): Administrative Contact, Legal Contact, Owner

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0960201	AQUARION WATER CO OF CT-MEADOWBROOK	C	396	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
			151		

Towns Served: BRIDGEWATER, NEW MILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (0999)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Asbestos (1094)		1 routine (RT) per nine years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21		
Total Haloacetic Acids (2456)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
RICH-CONN DRIVE SS-MB (04595)	1/1/18 - 12/31/18	8/1-8/31	Complete
	1/1/19 - 12/31/19	8/1-8/31	
	1/1/20 - 12/31/20	8/1-8/31	
Total Trihalomethanes (2950)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
2 STANDISH ROAD SS-MB (04594)	1/1/18 - 12/31/18	8/1-8/31	Complete
	1/1/19 - 12/31/19	8/1-8/31	
	1/1/20 - 12/31/20	8/1-8/31	
Total Coliform (3100)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0960201	AQUARION WATER CO OF CT-MEADOWBROOK	C	396	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
			151		

Towns Served: BRIDGEWATER, NEW MILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/19 - 10/31/19		

Lead And Copper (PBCU)	5 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	
	1/1/20 - 12/31/22	6/1-9/30	

Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: MONROE DR. PUMP HOUSE ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960201	AQUARION WATER CO OF CT-MEADOWBROOK			C	396	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			151				

Towns Served: BRIDGEWATER, NEW MILFORD

Monitoring Requirements

Water System Facility: **MONROE DR. PUMP HOUSE ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Pesticides, Herbicides and PCBs-Phase II (SOC2) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Pesticides, Herbicides and PCBs-Phase V (SOC5) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		Complete
	1/1/22 - 12/31/24		

Water System Facility: **WELL #1 (WSF ID: 369)**

E. Coli (3014) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #1 (2)	10/1/18 - 12/31/18		Complete

Water System Facility: **WELL #3 (WSF ID: 370)**

E. Coli (3014) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #3 (2)	10/1/18 - 12/31/18		Complete

Water System Facility: **WELL #5 (WSF ID: 371)**

E. Coli (3014) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #5 (2)	10/1/18 - 12/31/18		Complete

Water System Facility: **WELL #2 (WSF ID: 374)**

E. Coli (3014) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #2 (2)	10/1/18 - 12/31/18		Complete

Water System Facility: **WELL #10 (WSF ID: 378)**

E. Coli (3014) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #10 (2)	10/1/18 - 12/31/18		Complete

Water System Facility: **WELL #9 (WSF ID: 379)**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960201	AQUARION WATER CO OF CT-MEADOWBROOK			C	396	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			151				

Towns Served: BRIDGEWATER, NEW MILFORD

Monitoring Requirements

Water System Facility: **WELL #9 (WSF ID: 379)**

E. Coli (3014)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL #9 (2)	10/1/18 - 12/31/18		Complete	

Water System Facility: **WELL 4A (WSF ID: 48584)**

E. Coli (3014)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL 4A (2)	10/1/18 - 12/31/18		Complete	

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **MONROE DR. PUMP HOUSE ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.50 MG/L	Continuous	
Start Date: 3/1/2019				
		Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
		3/1/2019 - 3/31/2019	Y	Y
		4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7 PH	4	
Start Date: 12/1/2013				
		Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
		11/1/2018 - 11/30/2018		N
		12/1/2018 - 12/31/2018		N
		1/1/2019 - 1/31/2019		N
		2/1/2019 - 2/28/2019		N
		3/1/2019 - 3/31/2019		
		4/1/2019 - 4/30/2019		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	04594	2 STANDISH ROAD SS-M	A	Y		Y	Y
		04595	RICH-CONN DRIVE SS-M	A	Y			Y
		04595D	RICH-CONN DR SS - MB	A	Y			
		04595U	RICH-CONN DR SS - MB	A	Y			
		4	DISTRIBUTION SYSTEM	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0960201	AQUARION WATER CO OF CT-MEADOWBROOK			C	396	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				151				

Towns Served: BRIDGEWATER, NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MB-1	11 CAMBRIDGE CIRCLE	A	Y			
		MB-12	17 REVERE ROAD	A	Y	1		
		MB-13	8 RICHCONN DRIVE	A	Y	3		
		MB-14	9 RICHCONN DRIVE	A	Y	3		
		MB-16	17 GLENBROOK	A		1	Y	
		MB-3	12 STANDISH ROAD	A	Y	3		
		MB-4	23 STANDISH ROAD	A	Y	3		
		MB-5	31 STANDISH ROAD	A	Y	1		
		PB7095	2 CAMBRIDGE CIRCLE	A	Y	3		
		PB7096	22 JEFFERSON	A	Y	3		
		PB7097	9 MONROE DRIVE	A	Y	3	Y	
		PB7099	10 REVERE RD	A	Y	3		
		PB7100	4 REVERE ROAD	A	Y	3		
		PB7101	6 RICHCONN DRIVE	A	Y	3		
		PB7103	7 STANDISH ROAD	A		3		
		PB7104	47 STANDISH ROAD	A	Y	3		
		PB7105	27 CAMBRIDGE CIRCLE	A	Y	3		
		PB7106	8 STANDISH RD	A	Y	3		
		PB7107	11 STANDISH RD	A	Y	3		
		PB7108	15 STANDISH RD	A	Y	3		
		PB7109	1 MONROE DR	A	Y	3		
		PB7110	11 MONROE DR	A	Y	3		
		PB7111	19 STANDISH RD	A	Y	3		
		PB7112	7 JEFFERSON DRIVE	A	Y	3		
		PB7113	19 REVERE RD	A	Y	1		
		PB7114	10 CAMBRIDGE CIRCLE	A	Y	3		
		PB7115	18 CAMBRIDGE CIRCLE	A	Y	3		
		PB7116	6 REVERE RD	A	Y	3		
		PB7117	28 REVERE RD	A	Y	3		
		PB7118	41 STANDISH RD	A	Y	3		
		PB7119	16 CAMBRIDGE CIRCLE	A	Y	3		
		PB7132	2 GLENBROOK DRIVE	A	Y	3		
		PB7134	49 STANDISH RD	A	Y	3		
		PB7135	43 STANDISH RD	A	Y	3		
		PB7136	30 REVERE RD	A	Y	3		
		PB7178	12 STANDISH	A	Y			
		PB7910	31 STANDISH RD	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960201	AQUARION WATER CO OF CT-MEADOWBROOK			C	396	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			151				

Towns Served: BRIDGEWATER, NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB7911	38 STANDISH RD	A		1		
		PB7912	39 STANDISH RD	A		1		
		PB7913	42 STANDISH RD	A		1		
		PB7914	44 STANDISH RD	A		1		
		PB7915	5 GLENBROOK DR	A	Y	1		
		PB7916	7 GLENBROOK DR	A		1		
		PB7917	12 GLENBROOK DR	A		1		
		PB7918	6 CAMBRIDGE CIRCLE	A		1		
		PB7919	14 CAMBRIDGE CIRCLE	A		1		
		PB7920	25 CAMBRIDGE CIRCLE	A		1		
		PB7921	28 CAMBRIDGE CIRCLE	A		1		
		PB7922	14 JEFFERSON DR	A		1		
		PB7923	17 REVERE RD	A		1		
		PB7924	18 REVERE RD	A		1		
		PB7925	23 REVERE RD UNIT A	A		1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	MONROE DR. PUMP HOUSE ENTRY POINT	3	ENTRY POINT	A				
369	WELL #1	2	WELL #1	A				
370	WELL #3	2	WELL #3	A				
371	WELL #5	2	WELL #5	A				
374	WELL #2	2	WELL #2	A				
378	WELL #10	2	WELL #10	A				
379	WELL #9	2	WELL #9	A				
48584	WELL 4A	2	WELL 4A	A				
49385	MEADOWBROOK ATMOSPHERIC TANKS							
49387	MEADOWBROOK ATM TANK 2							
49391	MEADOWBROOK BOOSTER PUMPS(MONROE)							
527	MEADOWBROOK TREATMENT PLANT(MONROE)							
60215	PLEASANT VIEW INTERCONNECTION							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
---------------	---------------	------------------	--------------------------

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960201	AQUARION WATER CO OF CT-MEADOWBROOK			C	396	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			151				

Towns Served: BRIDGEWATER, NEW MILFORD

Certified Operator Information

LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021

Water System Facility: MEADOWBROOK TREATMENT PLANT(MONROE) (WSF ID: 527)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021

Contact Information

Name				Organization		Job Title			
Mr. John P. Walsh				Aquarion Water Company		Vice President			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
600 Lindley Street			Mail Stop 250			Bridgeport		CT	06606
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-337-5852			203-337-5938			781-413-6175	jwalsh@aquarionwater.com		

Contact Role(s): Administrative Contact, Legal Contact

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960211	CANDLEWOOD SPRINGS PROPERTY OWNERS ASSN			C	148	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			37				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) **1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22		

Total Coliform (3100) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Lead And Copper (PBCU) **5 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30	Complete
	1/1/18 - 12/31/20	6/1-9/30	
	1/1/21 - 12/31/23	6/1-9/30	

Physical Parameters (PPS) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate (1040) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960211	CANDLEWOOD SPRINGS PROPERTY OWNERS ASSN			C	148	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			37				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate (1040)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Nitrite (1041)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Net Gross Alpha (4000)		1 routine (RT) per six years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/19		Complete
	1/1/20 - 12/31/25		
Uranium (4006)		1 routine (RT) per six years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/19		Complete
	1/1/20 - 12/31/25		
Combined Radium-226/228 (4010)		1 routine (RT) per six years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/19		Complete
	1/1/20 - 12/31/25		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	2/26/2019
SUBMIT CCR CERTIFICATION FORM	8/9/2019	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960211	CANDLEWOOD SPRINGS PROPERTY OWNERS ASSN			C	148	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			37				

Towns Served: NEW MILFORD

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2021	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		CWS001	224 CWL RD	A	Y	3	Y	
		CWS002	17 CWL RD	A	Y	3	Y	
		CWS003	218 CWS RD	A	Y	3	Y	
		CWS004	230 CWS RD	A	Y	3	Y	
		CWS005	252 CWL RD	A	Y	3	Y	
		CWS006	46 CWL RD	A	Y	3	Y	
		CWS007	40 CWL RD	A	Y	3	Y	
		CWS008	34 CWL RD	A	Y	3	Y	
		CWS009	21 CWL RD	A	Y	3	Y	
		CWS010	7 CWL RD	A	Y	3	Y	
		CWS011	6 CWL RD	A	Y	3	Y	
		CWS012	10 CWL RD	A	Y	3	Y	
		CWS013	20 CWL RD	A	Y	3	Y	
		CWS014	25 CWL RD	A	Y	3	Y	
		CWS015	31 CWL RD	A	Y	3	Y	
		CWS016	30 CWL RD	A	Y	3	Y	
		CWS017	19 CWL RD	A	Y	3	Y	
		CWS018	37 CWL RD	A	Y	3	Y	
		CWS019	42 CWL RD	A	Y	3	Y	
		CWS020	24 CWL RD	A	Y	3	Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
337	CANDLEWOOD SPRINGS PROPERTY TP							
347	WELL 2	2	WELL 2	A				
46515	ATMOSPHERIC TANK							
56909	WELL 3	2	WELL 3	A				

Certified Operator Information

Water System Facility: CANDLEWOOD SPRINGS PROPERTY TP (WSF ID: 337)			
Facility Classification: CLASS 1 TREATMENT PLANT			
Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMAY, REALE D.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960211	CANDLEWOOD SPRINGS PROPERTY OWNERS ASSN			C	148	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			37				

Towns Served: NEW MILFORD

Certified Operator Information

Water System Facility: CANDLEWOOD SPRINGS PROPERTY TP (WSF ID: 337)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2020
KILBOURN, ERIC	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019

Contact Information

Name				Organization			Job Title		
Candlewood Springs Property Owners Assn									
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
Emergency Contact						Emergency Contact		CT	06000
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-350-2561									

Contact Role(s): **Owner**

Name				Organization			Job Title		
Mr. James Sproule				Candlewood Springs			President		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
256 Candlewood Lake Rd North						New Milford		CT	06776
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
203-417-2903						860-350-4344	jayspro10@gmail.com		

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960301	AQUARION WATER CO OF CT-PLEASANT VIEW			C	217	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			83				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (0999)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
8 DEBRA LANE SS-PV (04653)	1/1/18 - 12/31/18	8/10-8/16	Complete
	1/1/19 - 12/31/19	8/10-8/16	
	1/1/20 - 12/31/20	8/10-8/16	
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	
	1/1/20 - 12/31/22	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0960301	AQUARION WATER CO OF CT-PLEASANT VIEW			C	217	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				83				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Water System Facility: **ENTRY POINT - WELLS 5, 9, 10, 11, 11A (WSF ID: 00701)**

Net Gross Alpha (4000)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 9,11,11A (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Uranium (4006)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 9,11,11A (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Combined Radium-226/228 (4010)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 9,11,11A (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 9,11,11A (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 9,11,11A (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 9,11,11A (3)	1/1/17 - 12/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960301	AQUARION WATER CO OF CT-PLEASANT VIEW			C	217	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			83				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT - WELLS 5, 9, 10, 11, 11A (WSF ID: 00701)

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 9,11,11A (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: WELL #9 (WSF ID: 1487)

E. Coli (3014) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #9 (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: WELL #5 (WSF ID: 1556)

E. Coli (3014) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #5 (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: WELL #11 (WSF ID: 1828)

E. Coli (3014) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #11 (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: WELL #11A (WSF ID: 54814)

E. Coli (3014) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #11A (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: WELL #12 (WSF ID: 57923)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960301	AQUARION WATER CO OF CT-PLEASANT VIEW			C	217	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			83				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: WELL #12 (WSF ID: 57923)

E. Coli (3014)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL #12 (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT - WELLS 5, 9, 10, 11, 11A (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2012	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/30/2012	
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00500	BACKWASH RECYCLE SAMPLE TAP	2	RAW	A				
00501	BLEND OF RAW AND RECYCLE SAMPLE TAP	2	RAW	A				
00600	DISTRIBUTION SYSTEM	04653	8 DEBRA LANE SS-PV	A	Y		Y	Y
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB7159	4 MAPLEWOOD	A	Y	1		
		PB7160	14 MAPLEWOOD	A	Y	3		
		PB7161	26 MAPLEWOOD	A	Y	1		
		PB7162	27 MAPLEWOOD	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960301	AQUARION WATER CO OF CT-PLEASANT VIEW			C	217	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			83				

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB7163	5 MAPLEWOOD	A	Y	1		
		PB7164	12 MAPLEWOOD	A	Y	1		
		PB7165	23 MAPLEWOOD	A	Y	1		
		PB7370	3 MAPLEWOOD	A	Y	1		
		PB7900	2 PLEASANT VIEW RD	A	Y	1		
		PB7901	4 PLEASANT VIEW RD	A	Y	1		
		PB7902	5 PLEASANT VIEW DR	A	Y	1		
		PB7903	6 PLEASANT VIEW RD	A	Y	1		
		PB7904	18 MAPLEWOOD DR	A	Y	1		
		PV-1	8 PLEASANT VIEW DRIV	A	Y	1		
		PV-10	27 PLEASANT VIEW DRI	A	Y	1		
		PV-11	30 PLEASANT VIEW DRI	A	Y	1		
		PV-12	3 MAPLEWOOD DRIVE	A	Y	1		
		PV-13	4 MAPLEWOOD DRIVE	A	Y	1		
		PV-14	6 MAPLEWOOD DRIVE	A	Y	1		
		PV-15	26 MAPLEWOOD DRIVE	A	Y	1		
		PV-16	33 MAPLEWOOD DRIVE	A	Y	1		
		PV-17	34 MAPLEWOOD DRIVE	A	Y	1		
		PV-18	38 MAPLEWOOD DRIVE	A	Y	1		
		PV-19	41 MAPLEWOOD DRIVE	A	Y	1	Y	
		PV-2	5 PLEASANT VIEW DRIV	A	Y	1		
		PV-21	2 WEDGEWOOD DRIVE	A	Y	1		
		PV-22	8 WEDGEWOOD DRIVE	A	Y	1		
		PV-23	4 PLEASANT VIEW DRIV	A	Y	1		
		PV-3	6 PLEASANT VIEW DRIV	A	Y	1		
		PV-4	13 PLEASANT VIEW DRI	A	Y	1		
		PV-5	14 PLEASANT VIEW DRI	A	Y	1		
		PV-6	15 PLEASANT VIEW DRI	A	Y	1	Y	
		PV-7	20 PLEASANT VIEW DRI	A	Y	1		
		PV-8	21 PLEASANT VIEW DRI	A	Y	1		
		PV-9	24 PLEASANT VIEW DRI	A	Y	1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	ENTRY POINT - WELLS 5, 9, 10, 11, 11A	3	EP - WELLS 9,11,11A	A				
1487	WELL #9	2	WELL #9	A				
1556	WELL #5	2	WELL #5	A				
1828	WELL #11	2	WELL #11	A				
49401	PLEASANT VIEW ATM TANK 1							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960301	AQUARION WATER CO OF CT-PLEASANT VIEW			C	217	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			83				

Towns Served: NEW MILFORD

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
49403	PLEASANT VIEW ATM TANK 2							
49405	PLEASANT VIEW ATM TANK 3							
49407	PLEASANT VIEW ATM TANK 4							
51039	INTERCONNECTION AQUARION MEADOWBROOK SYS							
54814	WELL #11A	2	WELL #11A	A				
57923	WELL #12	2	WELL #12	A				
57926	DEBRA LANE PRESSURE TANK							
57928	PLEASANT VIEW CLEARWELL							
57930	DEBRA LANE PUMP STATION							
60217	PLEASANT VIEW BOOSTER							
749	PLEASANT VIEW TREATMENT PLANT							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: DISTRIBUTION SYSTEM

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021

Water System Facility: PLEASANT VIEW TREATMENT PLANT (WSF ID: 749)

Facility Classification: CLASS 2 TREATMENT PLANT

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021

Contact Information

Name		Organization	Job Title		
Mr. John P. Walsh		Aquarion Water Company	Vice President		
Mailing Address Line One	Mailing Address Line Two		City	State	Zip Code
600 Lindley Street	Mail Stop 250		Bridgeport	CT	06606

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0960301	AQUARION WATER CO OF CT-PLEASANT VIEW			C	217	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				83				

Towns Served: NEW MILFORD

Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-337-5852		203-337-5938		781-413-6175	jwalsh@aquarionwater.com

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0968011	AQUARION WATER CO OF CT-TWIN OAKS SYSTEM			C	152	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			58				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (0999)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
8 TWIN OAKS SS-TO (04668)	1/1/18 - 12/31/18	8/1-8/31	Complete
	1/1/19 - 12/31/19	8/1-8/31	
	1/1/20 - 12/31/20	8/1-8/31	
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/21	6/1-9/30	
	1/1/22 - 12/31/24	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0968011	AQUARION WATER CO OF CT-TWIN OAKS SYSTEM			C	152	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				58				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	3/1/19 - 3/31/19		Complete	
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Water System Facility: TWIN OAKS TP ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete	
	1/1/19 - 3/31/19		Complete	
	4/1/19 - 6/30/19			
	7/1/19 - 9/30/19			

Uranium (4006)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete	
	1/1/19 - 3/31/19		Complete	
	4/1/19 - 6/30/19			
	7/1/19 - 9/30/19			

Combined Radium-226/228 (4010)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete	
	1/1/19 - 3/31/19		Complete	
	4/1/19 - 6/30/19			
	7/1/19 - 9/30/19			

Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/18 - 12/31/20			
	1/1/21 - 12/31/23			

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete	
	1/1/19 - 12/31/19		Complete	
	1/1/20 - 12/31/20			

Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0968011	AQUARION WATER CO OF CT-TWIN OAKS SYSTEM			C	152	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			58				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: TWIN OAKS TP ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and PCBs-Phase II (SOC2) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Pesticides, Herbicides and PCBs-Phase V (SOC5) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: WELL #1 (WSF ID: 1688)

E. Coli (3014) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #1 (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: WELL #2 (WSF ID: 1689)

E. Coli (3014) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #2 (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: TWIN OAKS TP ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0968011	AQUARION WATER CO OF CT-TWIN OAKS SYSTEM			C	152	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			58				

Towns Served: NEW MILFORD

Water System Facility: **TWIN OAKS TP ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
4/1/2019 - 4/30/2019			

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	04668	8 TWIN OAKS SS-TO	A	Y	1	Y	Y
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB7503	56 TWIN OAKS	A		3		
		PB7504	47 TWIN OAKS	A		3		
		PB7505	7 TWIN OAKS	A		3		
		PB7506	30 TWIN OAKS	A		3		
		PB7507	51 TWIN OAKS	A		3		
		PB7508	10 TWIN OAKS	A		3		
		TO-1	9 TWIN OAKS	A	Y	1	Y	
		TO-2	2 TWIN OAKS	A	Y	1		
		TO-3	7 TWIN OAKS	A	Y	1		
		TO-5	12 TWIN OAKS	A	Y	1	Y	
		TO-6	38 TWIN OAKS	A	Y	1		
		TO-7	47 TWIN OAKS	A	Y	1		
		TO-8	51 TWIN OAKS	A	Y	1		
		TO-9	56 TWIN OAKS	A	Y	1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	TWIN OAKS TP ENTRY POINT	3	ENTRY POINT	A				
1688	WELL #1	2	WELL #1	A				
1689	WELL #2	2	WELL #2	A				
49463	TWIN OAKS TANK							
529	TWIN OAKS TREATMENT PLANT							
59238	BOOSTER STATION							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0968011	AQUARION WATER CO OF CT-TWIN OAKS SYSTEM			C	152	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			58				

Towns Served: NEW MILFORD

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: DISTRIBUTION SYSTEM

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021

Water System Facility: TWIN OAKS TREATMENT PLANT (WSF ID: 529)

Facility Classification: CLASS 1 TREATMENT PLANT

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021

Contact Information

Name		Organization		Job Title		
Mr. John P. Walsh		Aquarion Water Company		Vice President		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
600 Lindley Street		Mail Stop 250		Bridgeport	CT	06606
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-337-5852		203-337-5938		781-413-6175	jwalsh@aquarionwater.com	

Contact Role(s): Administrative Contact, Legal Contact

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0969361	AQUARION WATER CO OF CT-PARK GLEN SYSTEM			C	37	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
309 LITCHFIELD ROAD			14				
Towns Served: NEW MILFORD							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (0999)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete
	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
8 HARMONY TR SS- PG (04688)	1/1/18 - 12/31/18	8/1-8/31	Complete
	1/1/19 - 12/31/19	8/1-8/31	
	1/1/20 - 12/31/20	8/1-8/31	
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	
	1/1/20 - 12/31/22	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0969361	AQUARION WATER CO OF CT-PARK GLEN SYSTEM			C	37	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
309 LITCHFIELD ROAD			14				
Towns Served: NEW MILFORD							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0969361	AQUARION WATER CO OF CT-PARK GLEN SYSTEM			C	37	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
309 LITCHFIELD ROAD			14				
Towns Served: NEW MILFORD							

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/20		

Water System Facility: WELL 2 (WSF ID: 51968)

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: WELL 3 (WSF ID: 51974)

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3 (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 6/1/2006	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 10/1/2007	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0969361	AQUARION WATER CO OF CT-PARK GLEN SYSTEM			C	37	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
309 LITCHFIELD ROAD			14				
Towns Served: NEW MILFORD							

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	04688	8 HARMONY TR SS- PG	A	Y		Y	Y
		4	DISTRIBUTION	A				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB7166	4 RAINBOW CT	A	Y	N		
		PB7167	11 HARMONY TRAIL	A	Y	N		
		PB7168	17 HARMONY TRAIL	A	Y	N		
		PB7169	15 HARMONY TRAIL	A	Y	N		
		PB7170	18 HARMONY TRAIL	A	Y	N		
		PB7171	8 HARMONY TRAIL	A	Y	N		
		PB7906	2 RAINBOW CT	A	Y	N		
		PB7907	5 RAINBOW CT	A	Y	N		
		PB7908	1 BLOSSUM CT	A	Y	N		
		PB7909	6 BLOSSUM CT	A	Y	N		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
51966	WELL 1	2	WELL 1	A				
51968	WELL 2	2	WELL 2	A				
51974	WELL 3	2	WELL 3	A				
51990	TREATMENT PLANT							
51992	ATMOSPHERIC TANK							
51994	PUMP STATION							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification:

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0969361	AQUARION WATER CO OF CT-PARK GLEN SYSTEM			C	37	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
309 LITCHFIELD ROAD			14				
Towns Served: NEW MILFORD							

Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 51990)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021

Contact Information

Name		Organization		Job Title		
Mr. John P. Walsh		Aquarion Water Company		Vice President		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
600 Lindley Street		Mail Stop 250		Bridgeport	CT	06606
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-337-5852		203-337-5938		781-413-6175	jwalsh@aquarionwater.com	

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960221	AQUARION WATER CO OF CT-LAUREL RIDGE			C	80	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			20				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (0999)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/26		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
14 FIDDLEHAD DR SS (03786)	1/1/18 - 12/31/18	9/1-9/30	Complete
	1/1/19 - 12/31/19	9/1-9/30	
	1/1/20 - 12/31/20	9/1-9/30	
Lead And Copper (PBCU)		5 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/18 - 12/31/18		Complete
	1/1/19 - 6/30/19		
	7/1/19 - 12/31/19		
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960221	AQUARION WATER CO OF CT-LAUREL RIDGE			C	80	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			20				

Towns Served: NEW MILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: TREATMENT PLANT (WSF ID: 00700)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0960221	AQUARION WATER CO OF CT-LAUREL RIDGE			C	80	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			20				

Towns Served: NEW MILFORD

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: TREATMENT PLANT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2017	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	00004	LAUREL R/V DIST POIN	A	Y			
		03786	14 FIDDLEHAD DR SS	A	Y		Y	Y
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB8091	2 FIDDLEHEAD DR	A		N		
		PB8092	5 FIDDLEHEAD DR	A		N		
		PB8093	7 FIDDLEHEAD DR	A		N		
		PB8094	13 FIDDLEHEAD DR	A		N		
		PB8095	15 FIDDLEHEAD DR	A		N		
		PB8096	18 FIDDLEHEAD DR	A		N		
		PB8097	21 FIDDLEHEAD DR	A		N		
		PB8098	22 FIDDLEHEAD DR	A		N		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	TREATMENT PLANT	3	ENTRY POINT	A				
60737	WELL #2A	2	WELL #2A	A				
60739	WELL #3A	2	WELL #3A	A				
60742	WELL #4A	2	WELL #4A	A				
60744	ATMOSPHERIC TANK							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name		Classification	Population	Owner Type	Primary Source	
CT0960221	AQUARION WATER CO OF CT-LAUREL RIDGE		C	80	P	GW	
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			20				

Towns Served: NEW MILFORD

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification:

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021

Water System Facility: **TREATMENT PLANT (WSF ID: 00700)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021

Contact Information

Name		Organization		Job Title		
Mr. John P. Walsh		Aquarion Water Company		Vice President		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
600 Lindley Street		Mail Stop 250		Bridgeport	CT	06606
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-337-5852		203-337-5938		781-413-6175	jwalsh@aquarionwater.com	

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.